(See Regulation 2)

PUBLIC PROCUREMENT REGULATORY AUTHORITY (PPRA)

CONTRACT AWARD PROFORMA - I

To Be Filled And Uploaded On PPRA Website in Respect of All Public Contracts of Works, Services and Goods worth Fifty Million Rupees or More

NAME OF THE ORGANIZATION / DEPTT

National Transmission & Despatch

Company Limited (NTDCL)

FEDERAL / PROVINCIAL GOVT

Federal

TITLE OF CONTRACT

AFD-03-2023: Procurement

of

500kV/220kV 750MVA Auto-Transformer Bank for 500kV Sialkot Substation NTDC

TENDER NUMBER

AFD-03-2023

> BRIEF DESCRIPTION OF CONTRACT Procurement of (02+01) 500kV/220kV 750MVA Auto-Transformer Bank+ spare unit along with allied equipment and accessories etc.

- CONTRACT VALUE: EURO 12,986,410/-
- ENGINEER'S ESTIMATE

EURO: 12,824,232/-

- Delivery period is 330 days for CIP ESTIMATED COMPLETION PERIOD (Karachi) Pakistan contracts from the date of signing of contract.
- WHETHER THE PROCUREMENT WAS INCLUDED IN ANNUAL PROCUREMENT PLAN? YES
- ADVERTISEMENT:
 - PPRA Website (i)

Yes, Ref No. TS525787E

(Federal Agencies) (If yes give date and PPRA's tender number)

(ii) Newspaper

Yes. Published on 19th November 2023

TENDER OPENED ON (DATE AND TIME)

15th March 2024 at 11:30 AM

NATURE OF PURCHASE

International

- Yes. (Three extensions. One extension from EXTENSION IN DUE DATE (If any) ` 10th January 2024 to 31st January 2024 and then to 29th February 2024 and ultimately opened on 15th March 2024.)
- > NUMBER OF TENDER DOCUMENTS SOLD 5 (List Attached)
- WHETHER QUALIFICATION CRITERIA WAS INCLUDED IN BIDDING / TENDER DOCUMENTS Yes

101ntdc13325.pdp N

~	TENDER DOCUMENTS Yes Yes
~	WHICH METHOD OF PROCUREMENT WAS USED:- (Tick one)
	a. SINGLE STAGE – ONE ENVELOPE PROCEDURE
	b. SINGLE STAGE – TWO ENVELOPE PROCEDURE
	c. TWO STAGE BIDDING PROCEDURE
	d. TWO STAGE – TWO ENVELOPE BIDDING PROCEDURE
A	WHO IS THE APPROVING AUTHORITY Board of Directors (NTDC)
A	WHETHER APPROVAL OF COMPETENT AUTHORITY WAS OBTAINED FOR USING A METHOD OTHER THAN OPEN COMPETITIVE BIDDING Not Applicable.
~	NUMBER OF BIDS RECEIVED 03
A	WHETHER THE SUCCESSFUL BIDDER WAS LOWEST BIDDER Yes, Single Stage Single Envelop Bidding Procedure was used. Hence the Technically Responsive Bidder with least Cost was Selected
4	WHETHER INTEGRITY PACT WAS SIGNED Statement of Integrity, Eligibility and Social

& Environment Responsibility signed and attached in Contract Agreement Book.



PUBLIC PROCUREMENT REGULATORY AUTHORITY (PPRA)

CONTRACT AWARD PROFORMA - II


To Be Filled And Uploaded On PPRA Website in Respect of All Public Contracts of Works, Services and Goods worth Fifty Million Rupees or More

- NUMBER OF BIDDERS PRESENT AT THE TIME OF OPENING OF BIDS 03 Nos.
- NAME AND ADDRESS OF THE SUCCESSFUL BIDDER M/s Boading Tianwei Baobian Electric Co. Ltd. China (BTW) Through: Mr. Hamid Mehmood 28/42 Davis Road Lahore.
- RANKING OF SUCCESSFUL BIDDER IN EVALUATION REPORT 1st
- ➤ NEED ANALYSIS (Why procurement was necessary?) The procurement was essential for construction of 500kV Sialkot Grid Station
- WAS MADE IN RESPONSE TIME, WHAT WERE THE REASONS (Briefly describe)
 Yes. Three extensions were made because response against Pre-Bid Clarifications were pending.
- WHETHER NAMES OF THE BIDDERS AND THEIR PRICES WERE READ
 OUT AT THE TIME OF OPENING OF BIDS ______Yes/No
- ➤ DATE OF CONTRACT SIGNING 27th January 2025 (Copy of agreement attached)
- CONTRACT AWARD PRICE: EURO 12,986,410/-
- WHETHER COPY OF EVALUATION REPORT GIVEN TO ALL BIDDERS Yes, Evaluation Results were floated on NTDC / PPRA websites (Yes/No)
 (Bid evaluation results attached)
- ANY COMPLAINTS RECEIVED No (Yes/No) (If yes result thereof)
- > ANY DEVIATION FROM SPECIFICATIONS GIVEN IN THE TENDER NOTICE/ DOCUMENTS No (Yes/No) (If yes give details)
- DEVIATION FROM QUALIFICATION CRITERIA No (Yes/No) (If yes give details)
- SPECIAL CONDITIONS, IF ANY (Give brief description) No Special Conditions were agreed other than Contract Provisions.

[F.No.2/1/2008/PPRA -RA.III]



Sr.#	Name of Purchaser AFD-03-2023	
1.	M/s. AK-Ay Elektrik Dis Tic Koll Sri, Turkey	
	M/s. Inaam Energy Corporation	
	50-M, Main Gulberg-II, Lahore	
	Tel: 042-35756010, 35757565	
	Email: info@inaam-energy.com	
2.	M/s. TBEA Shenyang Transformer Group Co. Ltd. China	
	M/s. Alpine Enterprises Lahore	
	Office No. 509,510,516, National Tower, 28-Egerton Road, Lahore	
	Tel: 042-36311747, Fax: 042-36300457, Cell: 0333-4268063	
	Email: aqeel_shafi@hotmail.com	
3.	M/s. Shandong Power Equipment Co. Ltd. China	No.
٥.	, , , , , , , , , , , , , , , , , , ,	
	M/s. MK Engineers & Consultant Pvt. Ltd.	
0	65/1 FCC Syed Maratab Ali Road, Gulberg-IV, Lahore	
21	Tel: 042-35778186-88, Cell: 0322-7190952	
\cup	Email: ahsan@mkengineers.com.pk	5
4.	M/s. Boading Tianwei Baobian Electric Co. Ltd.	
1/	Mr. Hamid Mehmood	
0	28/42 Davis Road, Lahore	
11	Cell: 0309-9337379	
	Email: tender@btwelectric.com	
5.	M/s. Nantong Hyosung Transformer Co. Ltd. China	
1	M/s. 7AAYS Corporation	
	50-M, Main Gulberg-II, Lahore	
(3)	Tel: 042-35758050, Fax: 042-35758070	
11	Email: 7aays@abduls-group.com	



Description First Party

Second Party

Agent

Stamp Duty Paid by Issue Date

Paid Through Chattan

Amount in Words

AGREEMENT OR MEMORANDUM OF AN AGREEMENT - 5(CCC)

: BOADING TIANWEI BAOBIAN ELECTRIC CO LTD CHINA [3600000000000]

NTDC [30000000000000]

Sajawat [35202-4832428-7]

: BOADING TIANWELEAGBIAN ELECTRIC COLLID CHINA [300000000000]

: 28 Nov-2024, 03:43:49 PM

: 202443F5AF1F38D4

: One Thousand Two Hundred Rupees Only

Please Wase Relow This Line

Contract Agreement

THIS AGREEMENT made 2 7 JAN 2025

the day of December, 2024.

BETWEEN

- NATIONAL, TRANSMISSION AND DESPATCH COMPANY (NTDCL), a corporation incorporated under the laws of Pakistan and having its principal place of business at 8th Floor Shaheen Complex, Egerton Road, Lahore, Pakistan
- (2) BAODING TIANWEI BAOBIAN ELECTRIC CO. LTD,, a corporation incorporated under the laws of China and having its principal place of business at 2222 West Tianwei Road, Baoding Hebei China (hereinafter called "the Supplier").

WHEREAS the Purchaser invited bids for certain Goods and ancillary services, viz., AFD-03-2023: Procurement of 500kV/220kV 750MVA Auto-Transformer Bank for 500kV Sialkot Substation NTDC and has accepted a Bid by the Supplier for the supply of those Goods and Services in the sum of EURO 12,986,410/- (EURO Twelve Million Nine Hundred and Eighty-Six Thousand Four Hundred and Ten), (hereinafter called "the Contract Price").

NOW THIS AGREEMENT WITNESSETH AS FOLLOWS:

- In this Agreement words and expressions shall have the same meanings as are respectively assigned to them in the Contract documents referred to.
- The following documents shall be deemed to form and be read and construed as part of this Agreement. This Agreement shall prevail oger all other contract documents.











- The Letter of Acceptance No. CE/MP&M/M(MC)/AM-MC/AFD-03-2023/7377-80 Dated: 18-10-2024;
- The Bid Submission Form and Appendix to Bid Submission Form (including (b) the signed Statement of Integrity);
- The Addendum & Pre-Bid Clarifications (c)
- Special Conditions of Contract; (d)
- General Conditions of Contract; (e)
- The Specification (including Schedule of Requirements and Technical (f) Specifications);
- The completed Bidding Forms (including Price Schedules); (g)
- Any other document listed in GCC as forming part of the Contract. (h)
- In the event of any discrepancy or inconsistency within the Contract documents, then the documents shall prevail in the order listed above.
- In consideration of the payments to be made by the Purchaser to the Supplier as specified in this Agreement, the Supplier hereby covenants with the Purchaser to provide the Goods and Services and to remedy defects therein in conformity in all respects with the provisions of the Contract.
- The Purchaser hereby covenants to pay the Supplier in consideration of the provision of the Goods and Services and the remedying of defects therein, the Contract Price or such other sum as may become payable under the provisions of the Contract at the times and in the manner prescribed by the Contract.

IN WITNESS whereof the parties hereto have caused this Agreement to be executed in accordance with the laws of Pakistan on the day, month and year indicated above.

poral

For and on behalf of F National Transmission	& Despatch Company Limited (NTDCL) Muhammad Zahid lohal
Signed:	Chief Engineer (MP&M) NTDC 27-01-2-25 8th Floor, Shaheen Complex, Lahoru Muhammad Zahid Iqbal
In the Capacity of:	Chief Engineer (MP&M) NTDC
In the presence of:	Azhar Iaital Anjum Manger (MC
	• W

Baoding Tianwei Baobian Electric Co. Ltd.

Signed:

Name:

Lin Hongfu

In the Capacity of:

Sales Manager

In the presence of:

EVALUATION REPORT (As Per Rule 35 of PPRA Rules, 2004 Revised 2021)

National Transmission and Despatch Co. Ltd 1. Name of Procuring Agency (NTDCL) International Competitive Bidding (ICB) Method of Procurement 2 AFD-03-2023: Procurement of 500kV/220kV 750MVA 3. Title of Procurement Auto-Transformer Bank for 500kV Sialkot Substation NTDC 4. Tender Inquiry No. AFD-03-2023 PPRA Ref No. TS525787E 5. 15/03/2024 11:00 A.M. 6. Date & Time of Bid Closing Date & Time of Bid Opening 15/03/2024 11:30 A.M. 7. No of Bids Received 8. Criteria for Bid Evaluation Evaluation and Comparison of Bid as per Section-9. III "Evaluation and Qualification Criteria" of

Bidding Document

10. Details of Bid(s) Evaluation

	Ma	ırks	Read out Prices	Corrected/ Evaluated Bid	Award Price (CIP	Remarks	
Name of the Bidders	Technical (If Applicable	Financial (If Applicable)	(EURO)	Price (PKR)	Karachi) EURO		
M/s. Baoding Tianwei Baobian Electric Co. Ltd., China	NIL	NIL	12,986,410	7,440,740,549	12,986,410	Most Advantageous Bidder	
M/s. Nantong Hyosung Transformer Co. Ltd., China	NIL	NIL	15,066,300	7,854,628,072	Responsive l	out higher in	
M/s. Shandong Power Equipment Co. Ltd., China	NIL	NIL	 Reason of Non-responsiveness Failed to submit compliant Bid security, in accordance with the Instructions to Bidders Clause ITB 19.4, Section II, Bid Data Sheet. Schedule of technical data of 500kV Auto Transformer submitted with the bid does not conform to the tender requirement and specifications and there are major technical deviations / non-conformance of Highest voltage of Tertiary windings, lightning impulse withstand 				

voltage and Power frequency withstand voltage for
Tertiary windings of 500kV Auto Transformer.

11.	Lowest	Evaluated	Responsive	Bidder:	M/s.	Baoding	Tianwei	Baobian	Electric	Co.	Ltd.
	China.										

12. /	Anv	other additional,	supporting	information th	ne procuring	agency may	like to	share I	NIL
-------	-----	-------------------	------------	----------------	--------------	------------	---------	---------	-----

Signature:	
Official Stamp: CHIEF ENGINEER (MP&M) NTDC	

Note: The above evaluation results are based on detailed Evaluation Report and correct to best of our knowledge, however, in case of any discrepancy, the content of original Combined Evaluation Report shall prevail. Further the information is being published under PPRA Rules Revised June-2021 for information of all stakeholders.