



LAHORE CANTONMENT BOARD

42- Sarwar Road, Lahore Cantt.

Making Life Thrive

QUOTATION

Subject: - **SUPPLY/INSTALLATION/TESTING/COMMISSIONING OF 2 X 100KVA DIESEL GENERATOR FOR MAIN CANTT DISPOSAL STATION (GRANT-IN-AID)**

Online / Electronic tender is invited through web portal <https://etender.mlc.gov.pk> invited from contractors/manufacturers/suppliers to purchase of power generator with specifications given below to be installed at Main Cantt Disposal Station.

DETAILS AND SPECIFICATIONS OF ITEMS IS AS UNNDER:

Sr.#	Specification	Make	Qty.	Earnest Money (M)
1	Supply/Installation/Testing/Commissioning of Diesel Engine (100 KVA) Prime rating Generator in accordance with ISO-3046, ISO-9001:2015, BS-5514, DIN-6271, AS-2789, 2014/3/EU, electromagnetic compatibility and 2000/14/EC, noise emission for out door use Engine and alternator mounted on robust skid frame including fuel tank, fuel consumption, control panel, safety module diesel engine four stroke, water cooled 1500 RPM with safety protection, built in battery charger, batteries and brushless self-excited alternator, 400/230V, 3 phase and NL, 50 Hz, power factor 0.8 but without canopy, standard indication low oil pressure shut down, high coolant temperature shut down, earthing and foundation as per requirement. (CBU) Complete assembled, integrated/manufactured in EU, UK & USA. (100KVA)	CBU imported from EU, UK & USA.	01 No.	2% of bid amount
2	Supply/Installation/Testing/Commissioning of Diesel Engine (100 KVA) Prime rating Generator in accordance with ISO-3046, ISO-9001:2015, BS-5514, DIN-6271, AS-2789, 2014/3/EU, electromagnetic compatibility and 2000/14/EC, noise emission for out door use Engine and alternator mounted on robust skid frame including fuel tank, fuel consumption, control panel, safety module diesel engine four stroke, water cooled 1500 RPM with safety protection, built in battery charger, batteries and brushless self-excited alternator, 400/230V, 3 phase and NL, 50 Hz, power factor 0.8 but without canopy, standard indication low oil pressure shut down, high coolant temperature shut down, earthing and foundation as per requirement. Locally assembled CKD Unit from EU, UK & USA (100KVA)	Locally assembled, CKD unit from EU, UK & USA.	01 No.	2% of bid amount



LAHORE CANTONMENT BOARD

42- Sarwar Road, Lahore Cantt.

Making Life Thrive

3	Supply/Installation/Testing/Commissioning of Locally Fabricated weather and soundproof canopy, including main frame structure made of 14 SWG, epoxy painted insulation material (Glass wool), complete in all respect with noise level 84 dBA.	Locally Fabricated	02 No.	2% of bid amount
4	Cable electric PVC insulated, PVC sheathed, with stranded copper 70mm ² , 4 core, laid in PVC pipe/duct (excluding cost of pipe /duct), supply and fixing (as per site measurement).	Pakistan make	20 Mtr	2% of bid amount

CONDITIONS: - The general conditions for development work in Main Cantt area will be as under: -

- 1) Interested bidders can only submit their bids online through E-Tender Portal of ML& C Dept. (<https://etender.mlc.gov.pk>).
- 2) Contractors having valid NTN No. and SECP are eligible to apply.
- 3) The cut off time for submission of online bids will be 1200 hrs dated 13/06/2024 and shall be opened on same day at 1400 hrs electronically on the portal. The contractors will be able to see the comparative statement online.
- 4) E-tenders without attachment of call deposit / bond in favor of the undersigned as earnest money will be rejected.
- 5) The CDR's/Bid Security/earnest money shall be uploaded by all bidders. However, lowest bidder shall also deposit the said instrument (in original) in LCB office within 24Hours from the date of opening. In case of failure the bid shall not be considered, and the bidder shall be liable to face the consequences of all legal actions including blacklisting as per PPRA Rules.
- 6) The bid security/earnest money of successful bidder will be refunded after expiry of defect liability period i.e. 01 year after completion of work OR successful completion of audit which ever later.
- 7) All the successful bidders shall require to furnish a performance guarantee 6% of bid amount in the shape of Bank Guarantee from any Schedule Bank in Pakistan or insurance bond from reputed insurance company which shall be got approved from the LCB (in addition to earnest money) within 03 days after issuance of acceptance letter as per PPRA Rule,39. In case of failure the already deposited earnest money shall be forfeited and tender will be cancelled.
- 8) The Cantonment Board reserves the rights to demand the analysis of quoted rates to check their reasonability and workability.
- 9) The Cantonment Board / Executive Officer reserve the right to reject (prior to approval) the tender as per PPRA's Rule No. 33 due to any reason thereof.




LAHORE CANTONMENT BOARD

42- Sarwar Road, Lahore Cantt.

Making Life Thrive

- 10) The validity of tender rates for all works shall remain applicable for financial year 2023-24.
- 11) The successful contractor shall enter into a prescribed agreement (at their own cost on non-judicial stamp paper) with the CB Lahore within 07 days of issuance of acceptance letter.
- 12) The issuance of work order shall be subject to completion of all codal procedures i.e. (Sanction of CFA, approval of rates by the Board, submission of performance guarantee, and availability of funds etc.).
- 13) Work orders will be issued as per priority set by the authority, (quantity will be increased/decreased as per requirement).
- 14) Request of contractor for issuance of work order on the basis of any plea will not be entertained.
- 15) Any information regarding the E-Tender can be obtained from the office of undersigned during office hours. Furthermore, guidance tutorial has been uploaded on the portal.
- 16) No cheque/cash will be acceptable.
- 17) Conditional/multi optional tender/quotation will not be accepted.
- 18) All PPRA Rules and Govt. taxes (in vogue for the time being) are applicable.
- 19) Any tool/machinery kind of store /mobilization advance for execution of job will not be provided by LCB.
- 20) Escalation clause and secured advance are not applicable / admissible.
- 21) Overall rate of bid will be considered as lowest instead of single item rate.
- 22) The cost of making any test shall be borne by the contractor as per MES specification/requirement.
- 23) The Gen set for disposal station (Mechanical works/ Machinery), contractors are required to produce/submit purchasing order from original manufacturer regarding all the machinery/equipment's.
- 24) Payment will be made after verification of all equipment's from the manufacturer at site as per specifications and all the expenses (if any) will be borne by the contractor.


**Cantonment Executive Officer
Lahore**

Copy to:
Master file