


FINAL EVALUATION REPORT

(As Per Rule 35 of PP Rules,2004)

1. Name of Procuring Agency: MULTAN ELECTRIC POWER COMPANY LTD.,
MULTAN
2. Method of Procurement: Single Stage Two Envelope
3. Title of Procurement: For the procurement of 132KV Transformer CTs 100/200/5A
with Steel Supporting Structure.
4. Tender Inquiry No.: Tender No.03/2024-25
5. PPRA Ref. No. (TSE): TS544815E.
6. Date & Time of Bid Closing: 18.09.2024 at 11:00
7. Date & Time of Bid Opening: 18.09.2024 at 11:30
8. No of Bids Received: Two (02)
9. Criteria for Bid Evaluation: As per Bidding document
10. Details of Bid(s) Evaluation: As under:

Name of Bidder	Marks		Evaluated Cost (PKR)	Rule/Regulation/SBD*/Policy/ Basis for Rejection / Acceptance as per Rule 35 of PP Rules, 2004.
	Technical (if applicable)	Financial (if applicable)		
M/s PARAS Trading Company Karachi-Seven Star Company Karachi (JV)	Responsive	Responsive	97,800,000/-	---
M/s EMCO Industries Lahore.	Responsive	-	-	Grievance submitted by the M/s PARAS Trading against Technical responsiveness of M/s EMCO to GRC and accepted the grievance and decided that Grievance submitted by the M/s PARAS Trading against Technical responsiveness of M/s EMCO is correct, as M/s EMCO has quoted the Steel Supporting Structures from M/s EMCO whereas CT from EMEK Turkey with is violation of Technical Specification (NTDC Specification) P-90:2012 Clause 10.1 and definition of origin given at pate 95 to 125 under General Condition of contract (GCC) in bidding documents. hence the Technical responsiveness of M/s EMCO is not correct due to non-fulfillment of Technical Specification mentioned in bidding documents (Page 63 of 125) and hence set aside.

Lowest Evaluated Responsive Bidder: M/s PARAS Trading Company-Seven Star Company Karachi (JV).


**Addl. Chief Engineer (Proc.)
PMU MEPCO Multan**