

TECHNICAL EVALUATION REPORT

(As Per Rule 35 of PP Rules, 2004)

1. Name of Procuring Agency	LESCO
2. Method of Procurement	Single Stage Two Envelope
3. Title of Procurement	Rubber Insulating Gloves with Canvas Bags
4. Tender Inquiry No.	4121
5. PPRA Ref. No. (TSE)	TS550763E
6. Date & Time of Bid Closing	29.11.2024 10.30 a.m.
7. Date & Time of Bid Opening	29.11.2024 11.00 a.m.
8. No of Bids Received	One
9. Criteria for Bid Evaluation	As per Bidding Document
10. Details of Bid(s) Evaluation	As under

Name of Bidder	Marks		Evaluated Cost (Million Rs.)	Rule/Regulation/SBD*/ Policy/Basis for Rejection/ Acceptance as per Rule 35 of PP Rules, 2004.
	Technical (if applicable)	Financial (if applicable)		
Apparel & Textile Mills	--	--	--	Technically non-responsive bidder as detailed below: <ul style="list-style-type: none">The bidder not attached the certificate regarding the submission of bid bond.As per clause 8.2 of DDS-53:2020, the foreign manufacturer must be of the origin of USA, UK, France, Germany, Malaysia, Brazil, Spain, Japan, Poland and Australia whereas the offered material is Dipped Products PLC a Sri Lankan based firm.Bidder has neither provided valid prototype approval from CE(S&S) not attached any undertaking regarding the provision of the same before start the mass production.Bidder has not provided any document ascertaining the seven years manufacturing experience of the foreign manufacturer for similar gloves and satisfactory field performance of at least 5 years.Bidder has not provided the previous five years satisfactory performance.No technical data of the offered material submitted by the bidder.The test reports of the offered material were issued by the USA based laboratory named Akron Rubber Development Laboratory (ARDL) which is not listed in the laboratory names mentioned on page 5 of the tender documents.

Lowest Evaluated Bidder ---

11. Any other additional / supporting information, the procuring agency may like to share.

Endst. No. 6890-91

Dated: 03-01-2025

Forwarded to the Deputy Director, Public Procurement Regulatory Authority, 1st Floor FBC Building Near State Bank, Sector G-5/2, Islamabad for uploading at PPRA Website.

Info:

M/s Apparel & Textile Mills, MS Apparel House,
20-Km Main Ferozpur Road, Dulam Stop, Lahore

Chief Engineer (MM)
LESCO Ltd, Lahore

[Handwritten Signature]
03/01/25 31/1/25