



LAHORE ELECTRIC SUPPLY COMPANY

Chief Engineer (Development) PMU LESCO

132 kV Qartaba Grid Station Mozang Lahore

Ph: 042-99214410 FAX 042-99214412

EVALUATION REPORT (As per PPRA Rule 35, 2004)

1. Name of Procuring Agency	LESCO
2. Method of Procurement	Single Stage Single Envelope
3. Title of Procurement	11 kV O/C + E/F Relays
4. Tender Inquiry No.	687/PMU
5. PPRA Ref. No. (TSE)	TS549679E
6. Date & Time of Bid Closing	31-10-2024 @10.00 AM
7. Date & Time of Bid Opening	31-10-2024 @10.30 AM
8. No. of Bids received	Four (04)
9. Criteria for Bid Evaluation	As per Bidding Document
10. Detail of Bid(s) Evaluation	As under

Sr. No.	Name of Bidder	Results		Evaluated Cost (PKR)	Rule/Regulation/SBD*/Policy/ Basis for Rejection / Acceptance as per Rule 35 of PP Rules, 2004.
		Technical	Financial		
1	M/s Tariq Electric, Lahore	Responsive	Responsive	310,574,000	Responsive
2	M/s Creative Electronics, Lahore	Non-responsive	-	-	Firm does not fulfil the requirement of the bidding document as: i. Quoted relay does not exist in LESCO's system, hence, field performance can not be ascertained. ii. Test blocks are not mentioned in their covering letter as well as in the Form of Bid, which shows partial order of material. iii. Quoted relay is not approved from Design NTDC.
3	M/s Mighty Corporation, Lahore	Non-responsive	-	-	Firm does not fulfil the requirement of the bidding document as two of the beneficiary owners of M/s Mighty Corporation are also the shareholders of the M/s Siddique Sons. As M/s Siddique Son is not delivering the material to LESCO due to litigation, hence offer of M/s Mighty is declared as non-responsive as per clause 11.1 (a) 27 of the bidding document. i. As per clause 11 (o), firm is declared as non-responsive if the bidder has defaulted/did not supply/poor performance during the last three years/delivered substandard material in NTDC/WAPDA/DISCOs. ii. As per clause 11 (a).1 27, The bidder's Beneficiary Declaration certificate mentioning the names of Beneficiary accounts as per PPRA SRO 592 and in case, such owners / Beneficiary have



LAHORE ELECTRIC SUPPLY COMPANY

Chief Engineer (Development) PMU LESCO

132 kV Qartaba Grid Station Mozang Lahore


Ph: 042-99214410 FAX 042-99214412

					other firms with different names registered as General Order Suppliers with DISCOs/ NTDC/ WAPDA or any procuring agency who are consistently non-performing (Non-delivery of material, non-submission of Performance Guarantees, Bid Guarantees, Advance Payments, non-execution of contract agreements etc.) then the bidder's having same Beneficiary/ owners firm's shall be declared as non-responsive.
4	M/s Epesol, Lahore	Non-responsive	-	-	Firm does not fulfil the requirement of the bidding document as: i. Quoted relay does not exist in LESCO's system, hence, field performance can not be ascertained. ii. Quoted relay is not compliant to IEC 61850. iii. Quoted relay is not approved from Design NTDC.

Most Advantageous Bidders

M/s Tariq Electric Pvt. Ltd., Lahore

11. Any other additional/supporting information may be provided if required from procuring agency.


Chief Engineer (Dev.)
PMU LESCO

Endst. No. 16373-74

Dated: 10/12/2024

1. Forwarded to Deputy Director, Public Procurement Regulatory Authority, 1st Floor FBC Building Near State Bank, Sector G-5/2, Islamabad for uploading at PPRA website.
2. Forwarded to DG (MIS), LESCO for uploading the evaluation report result summary at LESCO website.