

EVALUATION REPORT
(As Per Rule 35 of PP Rules, 2004)

1. Name of Procuring Agency **National Transmission and Despatch Co. Ltd (NTDCL)**
2. Method of Procurement **International Competitive Bidding (ICB)**
3. Title of Procurement **PROCUREMENT OF TESTING EQUIPMENT FOR CE (TSG) NORTH & CE (TSG) SOUTH NTDC, UNDER NTDC'S OWN RESOURCES.**
4. Tender Inquiry No. **NOR-91R2-2021**
5. PPRA Ref No. **TS448852E**
6. Date & Time of Bid Closing **28/05/2021 at 11:00 A.M.**
7. Date & Time of Bid Opening **Technical: 28/05/2021 11:30 A.M.**

8. No of Bids Received

Item No.	1	2	3	4	5	6	7
No. of Bids	04	05	05	05	06	04	03

Item No.	8	9	10	11	12	13	14
No. of Bids	03	03	03	03	00	05	01

Item No.	15	16	17	18	19	20	21
No. of Bids	00	04	04	04	04	04	02

Item No.	22	23
No. of Bids	01	03

9. Criteria for Bid Evaluation

Evaluation and Comparison of Bid as per Section-I "Instructions to Bidders" of Bidding Documents

10. Details of Bid(s) Evaluation

Handwritten notes:
ntdcl 610
~~2021~~ 21. P
R. Ch 36328

Item No. 01: Universal Relay Testing Set:

Name of the Bidders	Marks		Technical Evaluation Results	Remarks
	Technical (If Applicable)	Financial (If Applicable)		
M/s Prescon Engineering (Pvt) Ltd., Lahore.	NIL	NIL	Responsive and recommended for price bid opening	Responsive
M/s AYK Pvt. Ltd., Gujranwala	NIL	NIL	Responsive and recommended for price bid opening	Responsive
M/s Megger Limited United Kingdom	NIL	NIL	Non-Responsive The bidder has not provided Power of Attorney as per tender document. In this regard, a post bid clarification was sought but the bidder failed to provide the same. Hence, the bidder is considered as non-responsive as per Clause IB.11 Section II of the bidding document.	
M/s. MN Enterprises Lahore	NIL	NIL	Non-Responsive The financial resources available with the firm are less than the required financial resources for Item 01. Hence, the firm is considered non-responsive against this item.	

Item No. 02: SFRA Test Set:

Name of the Bidders	Marks		Technical Evaluation Results	Remarks
	Technical (If Applicable)	Financial (If Applicable)		
M/s Prescon Engineering (Pvt) Ltd., Lahore.	NIL	NIL	Responsive and recommended for price bid opening	Responsive
M/s AYK Pvt. Ltd., Gujranwala	NIL	NIL	Responsive and recommended for price bid opening	Responsive
M/s. Unicom Corporation, Lahore.	NIL	NIL	Non-Responsive Manufacturer authorization for their offered M/s Megger was not provided by the bidder as required as per Clause IB.17 of Section II of the bidding document. So the bidder is not considered as responsive.	

M/s. HMZ Trading Co. Lahore.	NIL	NIL	Non-Responsive The bidder did not provide any required document to ascertain contractual, manufacturing & operational experience of offered test sets as per tender document in the bid. The same was asked via post bid clarification by the evaluator but no reply has been received. Therefore, the bid is incomplete and is rejected as per Clause IB 3A of the bidding document
M/s Megger Limited United Kingdom	NIL	NIL	<ul style="list-style-type: none"> Reasons are same as mentioned against Item No. 01

Item No. 03: Transformer Ohmmeter Test Set (Winding Resistance Test Set for 500kv Transformers:

Name of the Bidders	Marks		Technical Evaluation Results	Remarks
	Technical (If Applicable)	Financial (If Applicable)		
M/s AYK Pvt. Ltd., Gujranwala	NIL	NIL	Responsive and recommended for price bid opening	Responsive
M/s Megger Limited United Kingdom	NIL	NIL	Non-Responsive	<ul style="list-style-type: none"> Reasons are same as mentioned against Item No. 01
M/s. Continental Trading Corp. Lahore	NIL	NIL	Non-Responsive	The firm did not provide performance certificates to ascertain operational experience criteria as per Clause IB 3A a) 3. of tender document. Hence, the firm is considered non-responsive against these items.
M/s. MN Enterprises Lahore	NIL	NIL	Non-Responsive	The model WRT-10 offered by the firm is non-compliant since OC test voltage does not meet required criteria as per specification.
M/s. IBEKO Power AB DV Power Sweden	NIL	NIL	Non-Responsive	The bidder has provided audit reports in Swedish Language in the bid. A post bid clarification was invited from the bidder to provide audit reports in English. In their reply, the bidder could not provide English audit reports. Therefore, the bidder is substantially non-responsive as per Clause IB.10 Section I of the bidding document

Item No. 04: Transformer Turn Ratio (TTR) Test Set

Name of the Bidders	Marks		Technical Evaluation Results	Remarks
	Technical (If Applicable)	Financial (If Applicable)		
M/s. Continental Trading Corp. Lahore	NIL	NIL	Responsive and recommended for price bid opening	Responsive
M/s. MN Enterprises Lahore	NIL	NIL	Responsive and recommended for price bid opening	Responsive
M/s Megger Limited United Kingdom	NIL	NIL	Non-Responsive <ul style="list-style-type: none"> Reasons are same as mentioned against Item No. 01 	
M/s AYK Pvt. Ltd., Gujranwala	NIL	NIL	Non-Responsive <p>The firm five years' manufacturing experience criteria & performance criteria as per Clause IB 3A a) 2. & 3. of the bidding document could not be ascertained from the documents attached in the bid & in response to post bid clarifications.</p>	
M/s. IBEKO Power AB DV Power Sweden	NIL	NIL	Non-Responsive <ul style="list-style-type: none"> Reasons are same as mentioned against item No. 3. 	

Item No. 05: Circuit Breaker Contact Resistance Test Set

Name of the Bidders	Marks		Technical Evaluation Results	Remarks
	Technical (If Applicable)	Financial (If Applicable)		
M/s AYK Pvt. Ltd., Gujranwala	NIL	NIL	Non-Responsive <p>The model Miko 2.3 offered by the firm is non-compliant since operating temperature is not as per requirement.</p>	
M/s Megger Limited United Kingdom	NIL	NIL	Non-Responsive <ul style="list-style-type: none"> Reasons are same as mentioned against Item No. 01 	
M/s. Continental Trading Corp. Lahore	NIL	NIL	Non-Responsive <ul style="list-style-type: none"> Reasons are same as mentioned against item No. 3. 	

M/s. MN Enterprises Lahore	NIL	NIL	Non-Responsive The model Prime 600 offered by the firm is non-compliant since the maximum load capacity could not be ascertained from technical brochure of Prime 600.
M/s. IBEKO Power AB DV Power Sweden	NIL	NIL	Non-Responsive <ul style="list-style-type: none"> Reasons are same as mentioned against item No. 3.
M/s. Unicom Corporation, Lahore.	NIL	NIL	Non-Responsive <ul style="list-style-type: none"> Reasons are same as mentioned against item No. 2.

Item No. 06: Circuit Breaker Timing Test Set:

Name of the Bidders	Marks		Technical Evaluation Results	Remarks
	Technical (If Applicable)	Financial (If Applicable)		
M/s AYK Pvt. Ltd., Gujranwala	NIL	NIL	Responsive and recommended for price bid opening	Responsive
M/s Megger Limited United Kingdom	NIL	NIL	Non-Responsive <ul style="list-style-type: none"> Reasons are same as mentioned against Item No. 01 	
M/s. MN Enterprises Lahore	NIL	NIL	Non-Responsive The firm's five years manufacturing experience criteria and three years operational experience criteria could not be ascertained from the documents provided in the bid and in post bid reply too as per Clauses IB 3A a) 2 & 3. of the bidding document.	
M/s. IBEKO Power AB DV Power Sweden	NIL	NIL	Non-Responsive Reasons are same as mentioned against item No. 3.	

Item No. 07: Capacitance and Dissipation Factor (C&DF) 12kV Test Set:

Name of the Bidders	Marks		Technical Evaluation Results	Remarks
	Technical (If Applicable)	Financial (If Applicable)		
M/s AYK Pvt. Ltd., Gujranwala	NIL	NIL	Non-Responsive	

			The model CPC 80 + TD12 is non-compliant to technical specification since Capacitance measurement range do not meet required criteria as mentioned in specifications.
M/s Megger Limited United Kingdom	NIL	NIL	Non-Responsive <ul style="list-style-type: none"> Reasons are same as mentioned against Item No. 01
M/s. MN Enterprises Lahore	NIL	NIL	Non-Responsive <p>The model CAPO 12 offered by the firm is non-compliant since output power is under required rating as per specification.</p> <p>Moreover, the financial resources available with the firm are less than the required financial resources for Item 7. Hence, the firm is considered non-responsive against this item.</p>

Item No. 08: Oil Dielectric Strength (DES) Measurement Test Set (SARWAR ITTEHAD MEGGAR AYK)

Name of the Bidders	Marks		Technical Evaluation Results	Remarks
	Technical (If Applicable)	Financial (If Applicable)		
M/s AYK Pvt. Ltd., Gujranwala	NIL	NIL	Responsive and recommended for price bid opening	Responsive
M/s. MN Enterprises Lahore	NIL	NIL	Responsive and recommended for price bid opening	Responsive
M/s Megger Limited United Kingdom	NIL	NIL	Non-Responsive <ul style="list-style-type: none"> Reasons are same as mentioned against Item No. 01 	

Item No. 09: Clamp-on Meters (Upto Mill ampere Measurement Make Kyoritsu/Fluke/Equivalent approved):

Name of the Bidders	Marks		Technical Evaluation Results	Remarks
	Technical (If Applicable)	Financial (If Applicable)		
M/s AYK Pvt. Ltd., Gujranwala	NIL	NIL	Non-Responsive	

			The model F65 is non-compliant to technical specification since Operating Temperature Range is not as per required specifications.
M/s Megger Limited United Kingdom	NIL	NIL	Non-Responsive <ul style="list-style-type: none"> Reasons are same as mentioned against Item No. 01
M/s. Unicom Corporation, Lahore.	NIL	NIL	Non-Responsive <ul style="list-style-type: none"> Reasons are same as mentioned against item No. 2.

Item No. 10: Multimeter Make Kyoritsu/Fluke/Equivalent:

Name of the Bidders	Marks		Technical Evaluation Results	Remarks
	Technical (If Applicable)	Financial (If Applicable)		
M/s AYK Pvt. Ltd., Gujranwala	NIL	NIL	Non-Responsive The firm's five years manufacturing experience criteria as per Clause IB 3A a) 2. of the bidding document & performance criteria as per Clause IB 3A a) 3. of the bidding document could not be ascertained from the documents provided by the bidder.	
M/s Megger Limited United Kingdom	NIL	NIL	Non-Responsive <ul style="list-style-type: none"> Reasons are same as mentioned against Item No. 01 	
M/s. Unicom Corporation, Lahore.	NIL	NIL	Non-Responsive The model KEW 1021 R is non-compliant since the resistance and AC/DC voltage measurement ranges are not as per the requirements.	

Item No. 11: Phase Sequence Indicator approved

Name of the Bidders	Marks		Technical Evaluation Results	Remarks
	Technical (If Applicable)	Financial (If Applicable)		
M/s AYK Pvt. Ltd., Gujranwala	NIL	NIL	Responsive and recommended for price bid opening	Responsive
M/s. Unicom Corporation, Lahore.	NIL	NIL	Responsive and recommended for price bid opening	Responsive

M/s Megger Limited United Kingdom	NIL	NIL	Non-Responsive <ul style="list-style-type: none"> Reasons are same as mentioned against Item No. 01
--------------------------------------	-----	-----	--

Item No. 12: CT Polarity Indicator/Tester

None of the participants submitted bid against the item.

Item No. 13: Secondary Relay Test Set

Name of the Bidders	Marks		Technical Evaluation Results	Remarks
	Technical (If Applicable)	Financial (If Applicable)		
M/s AYK Pvt. Ltd., Gujranwala	NIL	NIL	Responsive and recommended for price bid opening	Responsive
M/s. MN Enterprises Lahore	NIL	NIL	Responsive and recommended for price bid opening	Responsive
M/s Megger Limited United Kingdom	NIL	NIL	Non-Responsive <ul style="list-style-type: none"> Reasons are same as mentioned against Item No. 01 	
M/s. Continental Trading Corp. Lahore	NIL	NIL	Non-Responsive Model RFD-200 S3 offered by the firm is non-compliant as it does not offer USB/Ethernet Communication	
M/s. Unicom Corporation, Lahore.	NIL	NIL	Non-Responsive <ul style="list-style-type: none"> Reasons are same as mentioned against item No. 2. 	

Item no. 14: DC Earth Fault Detector/DC Supply Detection Test Set

Name of the Bidders	Marks		Technical Evaluation Results	Remarks
	Technical (If Applicable)	Financial (If Applicable)		
M/s Megger Limited United Kingdom	NIL	NIL	Non-Responsive <ul style="list-style-type: none"> Reasons are same as mentioned against Item No. 01 	

Item no. 15: Temperature Gauge Calibrator Test Set:

None of the participants submitted bid against the item.

Item No. 16: Megger/Insulation Resistance Test Set:

Name of the Bidders	Marks		Technical Evaluation Results	Remarks
	Technical (If Applicable)	Financial (If Applicable)		
M/s. Continental Trading Corp. Lahore	NIL	NIL	Non-Responsive <ul style="list-style-type: none"> Reasons are same as mentioned against item No. 3. 	
M/s AYK Pvt. Ltd., Gujranwala			Non-Responsive The firm did not provide operational certificate of offered equipment as per Clause IB 3A a) 3. of the bidding document.	
M/s. Unicom Corporation, Lahore.	NIL	NIL	Non-Responsive <ul style="list-style-type: none"> Reasons are same as mentioned against item No. 2. 	
M/s Megger Limited United Kingdom	NIL	NIL	Non-Responsive <ul style="list-style-type: none"> Reasons are same as mentioned against Item No. 01 	

Item No. 17: Dew Point (SF6) Test Set

Name of the Bidders	Marks		Technical Evaluation Results	Remarks
	Technical (If Applicable)	Financial (If Applicable)		
M/s. Unicom Corporation, Lahore.	NIL	NIL	Responsive and recommended for price bid opening	Responsive
M/s. MN Enterprises Lahore	NIL	NIL	Non-Responsive The firm's five years manufacturing experience criteria as per Clause IB 3A a) 2. of the bidding document & performance criteria as per Clause IB 3A a) 3. of the bidding document could not be ascertained from the documents provided by the bidder in the bid and in response to post bid clarification as well.	
M/s Megger Limited United Kingdom	NIL	NIL	Non-Responsive <ul style="list-style-type: none"> Reasons are same as mentioned against Item No. 01 	
M/s. Continental Trading Corp. Lahore	NIL	NIL	Non-Responsive Model iSF6-1100 offered by the firm is non-compliant since the operating temperature range is not as per specifications.	

M/s AYK Pvt. Ltd., Gujranwala	NIL	NIL	Non-Responsive The firm did not provide operational certificate of offered test set, thus did not meet performance criteria as per Clause IB 3A a) 3. of the bidding document.
----------------------------------	-----	-----	--

Item no. 18: Purity (SF6) Test Set

Name of the Bidders	Marks		Technical Evaluation Results	Remarks
	Technical (If Applicable)	Financial (If Applicable)		
M/s. Unicom Corporation, Lahore.	NIL	NIL	Responsive and recommended for price bid opening	Responsive
M/s. MN Enterprises Lahore	NIL	NIL	Responsive and recommended for price bid opening	Responsive
M/s AYK Pvt. Ltd., Gujranwala	NIL	NIL	Non-Responsive The model FI-8000 SF6 is non-compliant to technical specification since its accuracy is not as per specifications.	
M/s. Continental Trading Corp. Lahore	NIL	NIL	Non-Responsive <ul style="list-style-type: none"> Reasons are same as mentioned against item No. 3. 	

Item No. 19: Primary Injection Test Set (2000A) (ISA SARWAR ITTEHAD MEGGAR AYK)

Name of the Bidders	Marks		Technical Evaluation Results	Remarks
	Technical (If Applicable)	Financial (If Applicable)		
M/s AYK Pvt. Ltd., Gujranwala	NIL	NIL	Responsive and recommended for price bid opening	Responsive
M/s. MN Enterprises Lahore	NIL	NIL	Responsive and recommended for price bid opening	Responsive
M/s Megger Limited United Kingdom	NIL	NIL	Non-Responsive <ul style="list-style-type: none"> Reasons are same as mentioned against Item No. 01 	
M/s. Continental Trading Corp. Lahore	NIL	NIL	Non-Responsive Model PC-U1 offered by the firm is non-compliant since the operating temperature range is not as per specifications.	

Item No. 20: Earth Resistance (Megger) Test Set (SARWAR MEGGAR AYK)

Name of the Bidders	Marks		Technical Evaluation Results	k
	Technical (If Applicable)	Financial (If Applicable)		
M/s. Unicom Corporation, Lahore.	NIL	NIL	<p>Non-Responsive</p> <ul style="list-style-type: none"> Reasons are same as mentioned against item No. 2. 	
M/s Megger Limited United Kingdom	NIL	NIL	<p>Non-Responsive</p> <ul style="list-style-type: none"> Reasons are same as mentioned against Item No. 01 	
M/s. Continental Trading Corp. Lahore	NIL	NIL	<p>Non-Responsive</p> <ul style="list-style-type: none"> Reasons are same as mentioned against item No. 3. 	
M/s AYK Pvt. Ltd., Gujranwala	NIL	NIL	<p>Non-Responsive</p> <p>The model C.A 6471's compliance to technical specifications could not be ascertained as technical data not provided. Hence the item is not acceptable.</p>	

Item No. 21: Battery Capacity Test Set

Name of the Bidders	Marks		Technical Evaluation Results	Remarks
	Technical (If Applicable)	Financial (If Applicable)		
M/s Megger Limited United Kingdom	NIL	NIL	<p>Non-Responsive</p> <ul style="list-style-type: none"> Reasons are same as mentioned against Item No. 01 	
M/s. IBEKO Power AB DV Power Sweden	NIL	NIL	<p>Non-Responsive</p> <ul style="list-style-type: none"> Reasons are same as mentioned against item No. 3. 	

Item no. 22: Battery Impedance Test Set

Name of the Bidders	Marks		Technical Evaluation Results	Remarks
	Technical (If Applicable)	Financial (If Applicable)		
M/s Megger Limited United Kingdom	NIL	NIL	<p>Non-Responsive</p> <ul style="list-style-type: none"> Reasons are same as mentioned against Item No. 01 	

Item No. 23: VLF Test Set

Name of the Bidders	Marks		Technical Evaluation Results	Remarks
	Technical (If Applicable)	Financial (If Applicable)		
M/s Megger Limited United Kingdom	NIL	NIL	Non-Responsive	<ul style="list-style-type: none"> Reasons are same as mentioned against Item No. 01
M/s. MN Enterprises Lahore	NIL	NIL	Non-Responsive	The firm's five years manufacturing experience criteria as per Clause IB 3A a) 2. of the bidding document & performance criteria of offered test set as per Clause IB 3A a) 3. of the bidding document could not be ascertained from the documents provided by the bidder.
M/s AYK Pvt. Ltd., Gujranwala	NIL	NIL	Non-Responsive	The firm's five years manufacturing experience criteria as per Clause IB 3A a) 2. of the bidding document & performance criteria of offered test set as per Clause IB 3A a) 3. of the bidding document could not be ascertained from the documents provided by the bidder.

11. Lowest Evaluated Responsive Bidder

Bidder	Item No.
M/s. Unicom Corporation, Lahore	11, 17 & 18
M/s. Continental Trading Corporation Lahore	4
M/s AYK Pvt. Ltd., Gujranwala	1, 2, 3, 6, 8, 11, 13 & 19.
M/s Prescon Engineering (Pvt) Ltd.	1, 2
M/s. MN Enterprises Lahore	4, 8, 13, 18 19
M/s. Prescon Engg. Pvt. Ltd, Lahore	1,2

12. Any other additional/supporting information, the procuring agency may like to share

Nil

Signature_____

Official Stamp CHIEF ENGINEER (MP&M)
NTDC

Note: The above evaluation results are based on detail Bid Evaluation Report (BER) and correct to best of our knowledge, however, in case of any discrepancy, the content of original BER shall prevail.