

Unit Payee Only



HBL
OPP. NEPCO COMPLEX,
KHANEWAL ROAD MULTAN

HABIB BANK
حیب بینک
0937

B.C. No. 27624763

Stationary No: 27624763

1	7	1	0	2	4
---	---	---	---	---	---

PKR *****135,000.00

PUBLIC PROCUREMENT REGULATORY AUTHORITY ISLAMABAD

Pay to _____ or Order

Rupees One Hundred Thirty Five Thousand Only.

Payable at any HBL Branch in Pakistan
Centralised Cheque Payable Account
30019903902586

M. USMAN HAIDER
P. No. 23255
HABIB BANK
HBL

Signatory
PA No.

FATIMA ARIF
24464
HBL

Please do not write below this line.

⑈ 27624763⑈054300⑈00300⑈9903902586⑈0⑈0⑈

TECHNICAL EVALUATION REPORT
(As Per Rule 35 of PP Rules,2004)

1. Name of Procuring Agency: MULTAN ELECTRIC POWER COMPANY LTD, MULTAN
2. Method of Procurement: Single Stage Two Envelope
3. Title of Procurement: For the procurement of Digital Energy Meters.
4. Tender Inquiry No.: Tender No.16/2024-25
5. PPRA Ref. No.(TSE): TS545777E.
6. Date & Time of Bid Closing: 19.09.2024 at 11:00
7. Date & Time of Bid Opening: 19.09.2024 at 11:30
8. No of Bids Received: One (01)
9. Criteria for Bid Evaluation: As per bidding document
10. Details of Bid(s)Evaluation: As under:-

Name of Bidder	Technical Marks (if applicable)	Rule/Regulation/SBD*/Policy/ Basis for Technical Rejection / Acceptance as per Rule 35 of PP Rules, 2004.
M/s JZ International Lahore	Responsive	---
M/s Infinity Lahore	Non-Responsive	Bidder has failed to meet the Technical Requirement. As per requirement Clamp-on Meter must be capable of measuring both AC/DC currents but the bidder has offered Clamp on Meter which is only for AC and does not fulfill the Specified requirements.
M/s Ittehad Electric. Co, Lahore	Non-Responsive	Bidder has failed to meet the Technical Requirement. As per requirement Clamp-on Meter must be capable of measuring both AC/DC currents but the bidder has offered Clamp on Meter but the bidder has offered CEM make Clamp on Meter having model DT-3353 which is only for AC instead of AC/DC and does not fulfill the Specified requirements.


Addl. Chief Engineer (Proc.)
PMU MEPCO Multan.