

EVALUATION REPORT

(As Per Rule 35 of PP Rules, 2004)

1. Name of Procuring Agency **National Transmission and Despatch Co. Ltd (NTDCL)**
2. Method of Procurement **International Competitive Bidding (ICB)**
3. Title of Procurement **For Procurement of 220kV & 132kV Circuit Breakers for 220/132kV Substation Jhamir-II, Jhampir-I & Mansehra**
4. Tender Inquiry No. **NOR-70BR4-2021.**
5. PPRA Ref No. **TS445207E**
6. Date & Time of Bid Closing (Technical) **15.04.2021 at 11:30 A.M.**
7. Date & Time of Bid Opening (Financial) **04.08.2021 at 11:00 A.M.**
8. No of Bids Received

Lot #	I	II
No. of Bids	02	01
9. Criteria for Bid Evaluation **Evaluation and Comparison of Bid as per Section-I "Instructions to Bidders" of Bidding Documents**
10. Details of Bid(s) Evaluation

LOT-I: 245kVCircuit Breakers

Name of the Bidders	Marks		Quoted Bid Prices (USD) CIF Karachi	Evaluated / Corrected Discounted Bid Price (USD) CIF Karachi	Remarks
	Technical (If Applicable)	Financial (If Applicable)			
M/s. Pinggao Group Company Limited China	NIL	NIL	USD: 2,010,119 (Bid Price) + USD: 1,134,164 (Price of Type Testing)	USD: 1,817,147.57 (Bid Price) + USD: 858,518 (Price of Type Testing)	Responsive
M/s. Herbin Electric International China.	NIL	NIL	Non-Responsive The bidder is non-responsive due to following reasons a) The delivery & Completion Schedule (Schedule-C to Bid) submitted with the bid shows major deviation in Delivery Period Offered. As per requirement of tender document, the required delivery period is of 240 days from Signing of contract agreement. However, the bidder offered delivery period of 7 Months with following conditions instead of criteria defined in tender document: 1) From the date of issuing of L/C 2) From the date of acceptance of type test report by the purchaser, which is latest. Therefore, the bidder doesn't fulfill the requirement of delivery & completion schedule as laid down in clause 12 Section-IV of tender document.		

6 ntdcl 26/02/21

26659

		<p>b) Regarding routine testing, the bidder doesn't comply with tender specification. The requirement for routine testing as per tender specification P-171:2008 is that all the routine tests will be carried out on each offered circuit breaker while the bidder quoted that: <i>"The general practice of routine tests witness is that witnessing of routine tests is carried out on no more than 10% of ordered units. However, all units are routine tested. The equipment prices quoted do not include any special arrangement exceeding above routine test witness arrangement. In case any special witness arrangements are required, they will be charged separately."</i></p> <p>Therefore, the bidder doesn't fulfill the requirement of routine testing as laid down in clause 26.1 Section-IV of tender document.</p> <p>c) The liquidated damages mentioned by the bidder are 0.01% of total contract price per day of delay instead of required 0.05%. Therefore, the bidder doesn't fulfill the requirement of liquidated damages as laid down in clause 27.1 Section-IV of tender document.</p> <p>a) These discrepancies come into major deviations; therefore, the bid is not substantially responsive as per clause IB.30 Section 1 of bidding document. Hence, the bidder is considered as non-responsive</p>
Contract Awarded		M/s. Pinggao Group Company Limited China Award Price: USD:1,817,147.57 + USD: 858,518 (Price of Type Testing)

LOT-II: 145kVCircuit Breakers

Name of the Bidders	Marks		Quoted Bid Prices (PKR) Excluding PST	Evaluated / Corrected Discounted Bid Price (PKR) (Excluding PST)	Remarks
	Technical (If Applicable)	Financial (If Applicable)			
M/s. Herbin Electric International China	NIL	NIL	Same reasons as stated against Lot-I		
Remarks:			LOT-II Recommended for Re-tendering		

1. **Lowest Evaluated Responsive Bidder**

Lot-I	M/s. Pinggao Group Company Limited China
Lot-II	Approved for re-tendering

2. **Any other additional / supporting Information, the procuring agency may like to share.**

NIL

Signature: _____

Official Stamp: CHIEF ENGINEER (MP&M), NTDC.

Note: The above evaluation results are based on detailed Bid Evaluation Report (BER) and correct to best of our knowledge, however, in case of any discrepancy, the content of original BER shall prevail.