



PAKISTAN
WATER AND POWER DEVELOPMENT AUTHORITY

Phone: 0938-281068
Fax: 0938-281057
Email: cetrbt4@gmail.com

OFFICE OF THE
CHIEF ENGINEER (O&M)
TARBELA 4th EXT. HYDEL POWER STATION

No. CE (O&M)/T4/REP/ITR/2021-22/ 3235

Dated 16 /02/2022

Director General

Public Procurement Regulatory Authority (PPRA)
1st Floor, FBC Building, near State Bank of Pakistan
Sector G-5/2, Islamabad.

Email: info@ppra.org.pk

Cell: 051-9205728-26.

Subject: **ANNOUNCEMENT OF EVALUATION REPORT (UNDER PPRA RULE- 35) AGAINST TENDER NO CE (O&M)/T4/ITR/17 IN RESPECT OF TARBELA 4th EXT. HPS.**

Reference: PPRA Rule - 35

Subsequent upon approval from competent authority, attached please find the duly filled and signed Evaluation Report regarding the subject tender pertaining to the following procurement in view of above referred PPRA Rule-35 for uploading on PPRA website.

- **CE (O&M)/T4/ITR/17** Procurement of complete key locks for 500 KV disconnect switches (Make: Castell or Equivalent, Type QKP1, Form 4, with electrical contacts 1NO+2NC, 6A/400V AC, IP 65, IEC 947-5-1) of 500 KV T4 switchyard on F.O.B. basis.

It is also confirmed that necessary funds are available for the publication of this Evaluation Report please.

Chief Engineer (O&M)
Tarbela 4th Ext: Hydel Power Station

CC

1. General Manager Hydel (Operation), WAPDA, 186 - Wapda House Lahore.
2. General Manager (Power), Tarbela.
3. M/s National Engineering Services, Trading and Consultancy Company, 3rd Floor, Suit No 01, Khyber Plaza, Fazal-UI-Haq Road, Blue Area, 46000, Islamabad.
4. M/s GLOW PAK INTERNATIONAL, 129/5-M, Quaid-e-Azam Industrial Estate, Kot Lakhpat, Lahore.

EVALUATION REPORT (As Per Rule 35 of PP Rules, 2004)

1. Name of Procuring Agency: Pakistan Water & Power Development Authority (WAPDA), Tarbela 4th Extension, Hydel Power Station, Tarbela.
2. Method of Procurement: Open competitive bidding (Single stage One Envelop Procedure).
3. Title of Procurement: Procurement of complete key locks for 500 KV disconnect switches (Make: Castell or Equivalent, Type QKP1, Form 4, with electrical contacts 1NO+2NC, 6A/400V AC, IP 65, IEC 947-5-1) of 500 KV T4 switchyard on **F.O.B. basis**.
4. Tender Inquiry No. : CE (O&M)/T4/ITR/17
5. PPRA Ref. No. (TSE) : TS459630E Published on 13.09.2021
6. Date & Time of Bid Closing: 14-10-2021 at 1100 Hrs.
7. Date & Time of Bid Opening: 14-10-2021 at 1130 Hrs.
8. No. of Bids Received: Two (02).
9. Criteria of Bid Evaluation: Technical: Compliance with the technical provisions of the bidding documents and scope of work.
Commercial: Compliance with the commercial/contractual conditions of the bidding documents.
10. Details of Bid(s) Evaluation: As below

Name of Bidder	Marks		Evaluated Cost	Rule/Regulation/ Standard Bidding Documents (SBD)/Policy/Basis for Rejection/Acceptance as per Rule 35 of PP Rules, 2004
	Technical (if applicable)	Financial (if applicable)		
M/s ODYSSEY GENERAL TRADING (FZC), Sharjah Airport International Free Zone, Sharjah UAE through M/s National Engineering Services, Trading and Consultancy Company Islamabad		---- N.A. ----	EURO 7,500/- (Rs. 1,490,090)	<ul style="list-style-type: none"> • The offer does not comply with technical provision of bidding documents as per Clause IB-16.7(a). • The offer also does not comply with the commercial provision of bidding documents as per Clause IB-16.7(b). Manufacturer's authorization is not submitted as per bidding data IB. 2.1 (i).
M/s FOX MOTOR, Shanghai FOX MOTOR CO. Limited Shanghai, China through M/s GLOW PAK INTERNATIONAL, Lahore			US\$ 13,860/- (Rs. 2,374,431)	<ul style="list-style-type: none"> • The offer does not comply with the commercial provision of bidding documents as per Clause IB-16.7(b). The bidder does not possess valid Manufacturer's authorization as per bidding data IB. 2.1 (i).

Lowest Evaluated Bidder: Re-tendering to ensure procurement of genuine product of required specification through more participation.

11. Any other additional/supporting information, the procuring agency may like to share.


 Chief Engineer (O&M)
 Tarbela 4th Ext: Hydel Power Station