

TECHNICAL EVALUATION REPORT

(As Per Rule 35 of PP Rules, 2004)

1	Name of Procuring Agency	IESCO
2	Method of Procurement:	Single Stage Two Envelope
3	Title of Procurement:	11 KV Load Break Switch (RMU)
4	Tender Inquiry No.:	146
5	PPRA Ref. No. (TSE):	TS552238E
6	Date & Time of Bid Closing:	19.12.2024 10:30 A.M
7	Date & Time of Bid Opening:	19.12.2024 11:00 A.M
8	No of Bids Received:	03
9	Criteria for Bid Evaluation:	As per Bidding Documents
10	Details of Bid(s) Evaluation	As under

Name of Bidder	Marks		Rule/Regulation/SBD* / Policy/Basis for rejection/Acceptance as per Rule 35 of PP Rules, 2004
	Technical (if applicable)	Financial (if applicable)	
M/s Pak Elektron Ltd. Lahore	Responsive	Yet to be Opened	Declared Technically Responsive by Technical Service Wing IESCO
M/s SkyPower (Pvt.) Ltd. Lahore	Responsive	Yet to be Opened	Declared Technically Responsive by Technical Service Wing IESCO
M/s M.k Engineering Works Lahore	Non - Responsive	Not to be Opened	Declared Non - Responsive by Technical Service Wing IESCO <ul style="list-style-type: none">Bidder failed to meet qualification criteria as per BDS clause 13.3b(iii) of bidding documents. Field performance of offered load break switch is not satisfactory.Bidder has not offered accessories required for re-fillable type system as per clause-9.4.1 to 9.4.5 of DDS-46:2009.Bidder failed to meet the tender specification requirement as per clause-9.4 of DDS-46:2009.

Name of Technically Responsive Bidder	M/s SkyPower (Pvt.) Ltd. Lahore
	M/s Pak Elektron Ltd. Lahore

No. 989

Dated: 30-01-25

Copy of above is hereby sent to Director (MIS) IESCO Islamabad for uploading on IESCO as well as PPRA Website.


Chief Engineer (MM)
IESCO Islamabad