

Memo No. 736-38 /CE(O&M)T&GDated: 22-03-24**Assistant Director-II**

Cabinet Division PPRA

Islamabad.

Subject: UPLOADING OF MEPCO TENDER EVALUATION REPORTS ON PPRA, WEBSITE

Enclosed please find the evaluation reports for the under mentioned tender for uploading on PPRA website.

Tender No.	Description
Tender No. RFP-03-RT/2023-24	Repairing / Overhauling of 132/11.5KV, 31.5/40MVA (05-Nos.) Power Transformers lying at different locations in MEPCO region. (Technical Evaluation)

DA/As Above
**Chief Engineer (O&M) T&G
MEPCO LIMITED MULTAN****C.C.TO:-**


- General Manager (Op) MEPCO Multan for information please.
- Mr. Khurram Javed (IT Officer) office of the Chief Executive MEPCO, Multan, for uploading of Technical evaluation reports on MEPCO, Website.

TECHNICAL EVALUATION REPORT

(As Per Rule 35 of PP Rules, 2004)

1.	Name of Procuring Agency:	MEPCO
2.	Method of Procurement:	Single Stage Two Envelope procedure
3.	Title of Procurement:	Repairing / Overhauling of 132/11.5KV, 31.5/40MVA (05-Nos.) Power Transformers lying at different locations in MEPCO region.
4.	Tender Inquiry No.:	Tender No. RFP-03-RT/2023-24
5.	PPRA Ref. No. (TSE):	TS528392E
6.	Date & Time of Bid Closing:	12.02.2024 12:00 Hrs.
7.	Date & Time of Bid Opening:	12.02.2024 12:30 Hrs.
8.	No. of Bids Received:	02 (Two)
9.	Criteria for Bid Evaluation:	As per bidding documents
10.	Details of Bid(s) Evaluation:	As under

Name of Bidder	Technical Evaluation	Rule/Regulation/SBD*/Policy/ Basis for Technical Rejection / Acceptance as per Rule 35 of PP Rules, 2004.
M/S PAK Electron Limited (PEL), Lahore	Responsive	
M/S Heavy Electrical Complex (HEC)	Non-Responsive	<ul style="list-style-type: none">The Bidder is not agree to conduct all Factory Acceptance Tests as per clause 12.1.1 of NTDC specifications P-46:2022 after repairing.The Bidder has offered warranty of repaired portion only instead of whole power transformer after repair for two years from the date of delivery or 18 months date of installation whichever is earlier while other bidder has accepted the GCC warranty clause 18.2 for complete transformer and will also performed the important test impulse voltage withstand test on repaired Power Transformer as per NTDC specification to ensure the effectiveness of the insulation system of a transformer.The bidder was requested vide email 04.03.2024 to submit undertaking that all clauses of bidding documents are acceptable to M/s HEC along with other clarification on observations but did not respond on it while submitting the reply.Integrity Pact duly signed and stamped not attached with bid.


Chief Engineer (O&M) T&G
MEPCO LIMITED MULTAN