



FAISALABAD ELECTRIC SUPPLY CO. LTD.

47
15

☎ 041-9220397
☎ 041-9220691
✉ cedevfesco@yahoo.com

Office of the,
Chief Engineer (Development),
PMU FESCO Faisalabad

EVALUATION REPORT

(As per Rule 35 of Public Procurement Rules, 2004)

- Name of Procuring Agency: Faisalabad Electric Supply Company (FESCO)
- Method of Procurement: Single Stage Single Envelope
- Title of Procurement: 132KV Non Ceramic Polymer Insulators (Composite) 100-KN as per WAPDA/NTDC Specification TLMS-8A:2017 (amended to date) Minimum Leakage Distance 5616 (mm) & Maximum Permissible Section Length 1898 (mm) (LOT-I/(GSC), LOT-II/(Deposit Work) & LOT-III/(GSO)
- Tender Inquiry No.: NCB-590/FESCO/PMU/GSC&GSO&DW/2023-24
- PPRA Ref. No. (TSE): TS530807E dated 23.01.2024
- Date & Time of Bidding Closing: 11:00 A.M. 06.02.2024
- Date & Time of Bidding Opening: 12:30 P.M. 06.02.2024
- No. of Bids Received: 03 No.
- Criteria for Bid Evaluation: As per Bidding Document

10 Details of Bids (s) Evaluation As under:

Name of Bidder	Marks		Evaluated Cost (Million Rs.)	Rule/Regulation/SBD/Policy/Basis for Rejection/Acceptance as per Rule 35 of PP Rules, 2004
	Technical (If applicable)	Financial (If applicable)		
Junaid (Pvt) Ltd	---	---	164.430 (LOT-I)	The bid declared Commercially & Technically Responsive.
			99.486 (LOT-II)	
Associated Commercial Agencies (Pvt) Ltd	---	---	130.318 (LOT-I)	The bid declared Commercially & Technically Responsive.
			61.747 (LOT-II)	
			34.342 (LOT-III)	
M.N. Enterprises	---	---	158.095 (LOT-I)	i) The bid declared Commercially Responsive. ii) The bid declared Technically Non-Responsive due to: ➤ The bidder did not submit an undertaking to perform fresh type test as per Revised NTDC Type Test Policy and not in line with Clause-7.3 (Type Test Report), Section-III, Evaluation & Qualification Criteria of bidding documents.
			74.909 (LOT-II)	
			41.662 (LOT-III)	

Lowest Evaluated Bidder: M/s Associated Commercial Agencies (Private) Limited, Lahore


A fesco 16024 - 5

11. Any other additional/supporting information, the procuring agency may like to share.

Endst. No. 7545-46 /CE(Dev)PMU FESCO

Dated: 14-5-24

Forwarded to the Deputy Director, Public Procurement Regulatory Authority, 1st Floor, FBC Building, Near State Bank, Sector G-5/2, Islamabad for uploading at PPRA Website.


13/05/24
Chief Engineer (Development)
PMU, FESCO, Faisalabad

CC:-

1. Director General (IT) FESCO Faisalabad with the request to upload on FESCO website please.
2. Master File.