



# FAISALABAD ELECTRIC SUPPLY CO. LTD.

45  
5

☎ 041-9220397  
☎ 041-9220691  
✉ cedevfesco@yahoo.com

Office of the,  
Chief Engineer (Development),  
PMU FESCO Faisalabad

## EVALUATION REPORT

### (As per Rule 35 of Public Procurement Rules, 2004)

1. Name of Procuring Agency Faisalabad Electric Supply Company (FESCO)
2. Method of Procurement Single Stage Two Envelope
3. Title of Procurement
  - i) Manual Hydraulic Press Machine with Steel die set (70mm, 95mm, 120mm, 240mm & 500mm) Minimum Capacity 50-Ton (Make Europe/UK/USA) or equivalent
  - ii) Hydraulic Conductor Cutter for Transmission Lines 40mm dia minimum (Make Europe/UK/USA) or equivalent
  - iii) Temporary Earthing set for 132KV Transmission Line with 10 feet minimum Length Rod, shotgun type, Duck Bill Clamp for Earth (PTE), T-Clamp for Earth (PTE), lightweight Copper Cable (1/2") for Earth Lead (PTE) (15 Feet each Lead) (Make Europe/UK/USA) or equivalent
  - iv) Ratchet Conductor Cutter Gear-Chain Type (Make Europe/UK/USA) or equivalent
  - v) Snatch Block/Ruler for Hand Line 2", 1 Ton (Make Europe/UK/USA/Canada) or equivalent
4. Tender Inquiry No. NCB-436/PMU/FESCO/GSO(T&P)/2022-23
5. PPRA Ref. No. (TSE) TS502100E dated 01.02.2023
6. Date & Time of Bidding Closing 11:00 A.M. 12.04.2023
7. Date & Time of Bidding Opening 11:30 A.M. 12.04.2023
8. No. of Bids Received 02 Nos.
9. Criteria for Bid Evaluation As per Bidding Document
10. Details of Bids (s) Evaluation As under:

Item Description	Name of Bidder (M/s)	Marks	Rule/Regulation/SBD/Policy/Basis for Rejection/Acceptance as per Rule 35 of PP Rules, 2004
		Technical (If applicable)	
Manual Hydraulic Press Machine with Steel die set	Continental Trading Corporation	---	Technically Responsive
	Shah Gee Enterprises	---	Technically Non-Responsive due to Blade worn out after use & disabled after one press

D:\GSC&GSO Data\2022-23\Letters\Evaluation Report Proforma.doc

22 FESCO 6623 - P202

57599

Item Description	Name of Bidder (M/s)	Marks	Rule/Regulation/SBD/Policy/Basis for Rejection/Acceptance as per Rule 35 of PP Rules, 2004
		Technical (If applicable)	
Hydraulic Conductor Cutter for Transmission Lines	Continental Trading Corporation	---	Technically Responsive
	Shah Gee Enterprises	---	Technically Non-Responsive due to sub standard material, More force required during operation & slow press
Temporary Earthing set for 132KV Transmission Line	Continental Trading Corporation	---	Technically Responsive with the condition that to provide this item along with the clamp jaws opening of at least 70mm and 50mm <sup>2</sup> dia of copper cable
Ratchet Conductor Cutter Gear-Chain Type	Shah Gee Enterprises	---	Technically Non-Responsive due to designed for Cable Cutting instead of Steel Wire
Snatch Block/Ruler for Hand Line 2", 1 Ton	Continental Trading Corporation	---	Technically Responsive
	Shah Gee Enterprises	---	Technically Non-Responsive due to unreliable/low quality hook

Endst. No. 9022-23 /CE(Dev)PMU FESCO

Dated: 02-06-23

Forwarded to the Deputy Director, Public Procurement Regulatory Authority, 1<sup>st</sup> Floor, FBC Building, Near State Bank, Sector G-5/2, Islamabad for uploading at PPRA Website.

*Amir M. Ishaq*  
Chief Engineer (Development)  
PMU, FESCO, Faisalabad

CC:-

- Director General (IT) FESCO Faisalabad with the request to upload on FESCO website please.