## EVALUATION REPORT (As Per Rule 35 of PP Rules, 2004)

1. Name of Procuring Agency:

HQ NADRA Islamabad

2. Method of Procurement:

Single Stage (02) Envelope Methods

3. Title of Procurement:

Supply, Installation and Commissioning of 300KVA UPS with Allied Equipment

4. Tender Inquiry No.:

NADRA-HQ-RFB-62/2024

5. PPRA Ref. No. (TSE):

TS535765E

6. Date & Time of Bid Closing:

29th April, 2024 At 11:00 hrs.

7. Date & Time of Bid Opening:

29th April, 2024 At 11:30 hrs.

8. No of Bids Received:

06x Bids

9. Criteria for Bid Evaluation:

As per Eligibility & Technical Evaluation Criteria Mentioned

in Tender Documents

10. Details of Bid(s) Evaluation:

As under: -

	Marks			Rule/Regulation/SBD*/Policy/ Basis			
Name of Bidder	Technical (If applicable)	Financial (If applicable)	Evaluated Cost	for Rejection / Acceptance as per Rule 35 of PP Rules, 2004.			
M/s Premier System	Qualified	Only Technical qualification was required	Rs.97,975,474/-	Bids of Six firms i.e. M/s Premier System, M/s Business Excellence, M/s Computer			
M/s Business Excellence	Qualified	Only Technical qualification was required	Rs.189,013,694/-	Marketing System, M/s Silicon Technology, M/s Innovative Energy Solution & M/s Fortek were received. Bids			
M/s Computer Marketing System	Qualified	Only Technical qualification was required	Rs.102,513,863/-	were opened on 29 <sup>th</sup> April, 2024. bid of M/s Innovative Energy Solution was Non responsive due to inactive tax payer and bid			
M/s Silicon Technology	Qualified	Only Technical qualification was required	Rs.98,513,324/-	of M/s Fortek was technically disqualified. Financial bids of the technically qualified firm were opened on 16 <sup>th</sup> May, 2024. As per			
1/s Innovative nergy Solution		Non-Respons	ive	Financial evaluation bid of M/s Premi System was found most advantageo bidder.			
M/s Fortek		disqualified	I	olddel.			

Lowest Evaluated Bidder:

M/s Premier System

11. Any other additional / supporting information, the procuring agency may like to share. Nil

Imran Hashim Deputy Director NADRA Procurement Dated 4 June,2024

3 nadsa 24624. Pg

Technical Evaluation for Supply, installation of Data Center Grade, 3-Phase Modular & Scalable 300KW UPS with Lithium ION Batteries for NADRA Data center

(Tender # NADRA - HO	) - RFB	- 62/	2024)
----------------------	---------	-------	-------

No		Evaluation Matrix	Max Marks	Marks / Weightage distribution criteria	M/S Promier Systems (Vertiv UPS SORW PM & Coolings	M/S Business Excattence (APC Schholder UPS & Coding)	M/S Silicon Technologies (Vertiv UPS 66KW PM & Cooling)	N/S Fortek (Huswei fokw PM, Stutz Coolling)	M/S Computer Marketing Company (Versiv UPS BOKW PM S Cooling)	
1	Bidder Qualifi	Bidder Qualifications, Projects & Customer References								
		The Bidder must have successfully installed similar reduce project of comparable scale, preferably in Pakistan	25	03 Installed = 25 Marks	25		25	9	15	
	Relevant			02 Installed = 15 Marks		25				
	Expenence			Q1 Installed = 10 Marks						
		How good are their references regarding their experience with GOP/Defense and General client with their installation and service for UPS's	26	a) GQP	10	25	10	0	15	
				b) Defense						
	n n n .			c) General Chent						
	(K)P./ Clemenal Closes			if all Three = 25 Marks						
				if any Two = 15 Marks						
				If anyone = 10 Marks						
				it none = Zero Marks						
	Installation		10	Installation = 10 Marks	10	10	10	0	10	
	Experience	Bidder experience in installing UPS in a running DC.		No Installation × Zero Marks	1		1	1		
2	Qualification	Qualifications of Management and Technical Team								
AL establish	Technica: Team	Must be cartified with Principal / Manufacturer of the proposed solution. Prease specify with detail of qualification and experience of the Technical teem.	10	Principal / Manufacturer certified = 10 Marks Max. (05 Marks per trained staff)	10	10	10	5	10	
	Solution Presentation	Solution presentation a) Rehability of the Solution and Battery technology b) Redundancy and fault tolerance c) Monitoring and management d) Compatibility and integration e) implementation plan and I ayout including steps of UPS installation and Understanding of the current System f) Service and support Attach PPT / Document / Presentation	30	05 Marks for each topic 06 Marks for no presentation of solutions	30	30	30	35	30	
		Total Marks	100		85 Qualified	100		Not Custifie		
	Qualified / Not Qualified					Qualified	Qualified	Legal Paragraphica	A Mercanistan	

Only those firms will qualify who will obtain minimum 65 marks.

President:

Mr. Moharpmad Yasir Rafique

Deputy Director (Networks)

Member

/Mr. Javed Saldar Electronics Engineer (Networks Dte)

Mr. Haroon Hafeez Ahmed

Daputy Director (Technology Dte)

Deputy Director (Technology Dte)