

EVALUATION REPORT
(As Per Rule 35 of PP Rules, 2004)

1. Name of Procuring Agency **National Transmission and Despatch Co. Ltd (NTDC)**
2. Method of Procurement **International Competitive Bidding (ICB) & Single Stage Two Envelope (SSTE)**
3. Title of Procurement **PROCUREMENT OF 132/11.5KV, 20/26MVA POWER TRANSFORMER FOR 220/132KV SUBSTATION JHAMPIR-II**

4. Tender Inquiry No. **NOR-70T-2021**
5. PPRA Ref No. **TS446177E**
6. Date & Time of Bid Closing **16/04/2021 at 11:00 A.M.**
7. Date & Time of Bid Opening **Technical: 16/04/2021 At 11:30 A.M.**
Financial: 11/06/2021 At 10:30 A.M.

8. No of Bids Received **Two (02)**
9. Criteria for Bid Evaluation **Evaluation and Comparison of Bid as per Section-I "Instructions to Bidders" of Bidding Documents**
10. Details of Bid(s) Evaluation

Name of the Bidders	Marks		Quoted Bid Price Exclusive of GST (PKR)	Corrected/Evaluated Bid Price Exclusive of GST (PKR)	Inland Transportation Charges	Remarks
	Technical (If Applicable)	Financial (If Applicable)				
M/s. Pak Electron Limited, Lahore.	NIL	NIL	66,500,000/-	66,500,000/-	500,000/-	Responsive
M/s Bambang DJAJA (B&D) Transformer), Indonesia	<p>Reasons of Non-Responsiveness</p> <p>Following are the reasons of non-responsiveness of the bidder:</p> <ol style="list-style-type: none"> a) The bidder has mentioned short circuit duration to be 2 seconds instead of required 3 seconds as per requirement of NTDC Specification P-46:2008. b) The design flux density quoted by the bidder is 1.72 Tesla which will make maximum flux density at over voltage operation equals to 2.0984T which is much higher than required value 1.9 Tesla as per clause 4.6.3 of P-46:2008. c) Asymmetrical Short Circuit Current values mentioned in SOTD at Sr. No. 24(a) (i&ii) are 40kA for both HV & LV windings against required values 2.73kA & 28.16kA. d) The lightning impulse voltage test on LV side of the offered power transformer quoted by the bidder is mentioned as 75kV instead of required 110kV as per tender specification. 					

ntdc 19721. P 38305

	<ul style="list-style-type: none"> e) The separate source power frequency test voltage for LV Winding is mentioned as 28kV instead of required value 38kV as per tender specification. f) The schedule of technical data submitted with the bid is not properly filled. g) The bidder didn't provide undertaking of bid security on non-judicial stamp paper as per requirement of Appendix-Q of tender document. h) The bidder neither provided type test reports of offered 132/11.5kV, 20/26MVA Power Transformer nor submitted any undertaking to perform type testing as per requirement of clause 3 Section VI of tender document. i) The bidder did not submit comfort letter from any scheduled bank of Pakistan. j) Submitted power of attorney is not duly attested by Pakistan Embassy/Consulate General of Pakistan.
--	--

1. Lowest Evaluated Responsive Bidder

M/s. Pak Electron Limited, Lahore.

2. Any other additional/supporting information, the procuring agency may like to share

Nil

Signature _____

Official Stamp CHIEF ENGINEER (MP&M) NTDC

Note: The above evaluation results are based on detailed Bid Evaluation Report (BER) and correct to best of our knowledge, however, in case of any discrepancy, the content of original BER shall prevail

EVALUATION REPORT
(As Per Rule 35 of PP Rules, 2004)

- | | | |
|-----|------------------------------|--|
| 1. | Name of Procuring Agency | <u>National Transmission and Despatch Co. Ltd (NTDC)</u> |
| 2. | Method of Procurement | <u>International Competitive Bidding (ICB) & Single Stage Two Envelope (SSTE)</u> |
| 3. | Title of Procurement | <u>PROCUREMENT OF 132/11.5KV, 20/26MVA POWER TRANSFORMER FOR 220/132KV SUBSTATION JHAMPIR-II</u> |
| 4. | Tender Inquiry No. | <u>NOR-70T-2021</u> |
| 5. | PPRA Ref No. | <u>TS446177E</u> |
| 6. | Date & Time of Bid Closing | <u>16/04/2021 at 11:00 A.M.</u> |
| 7. | Date & Time of Bid Opening | <u>Technical: 16/04/2021 At 11:30 A.M.</u>
<u>Financial: 11/06/2021 At 10:30 A.M.</u> |
| 8. | No of Bids Received | <u>Two (02)</u> |
| 9. | Criteria for Bid Evaluation | <u>Evaluation and Comparison of Bid as per Section-I "Instructions to Bidders" of Bidding Documents</u> |
| 10. | Details of Bid(s) Evaluation | |

Name of the Bidders	Marks		Quoted Bid Price Exclusive of GST (PKR)	Corrected/Evaluated Bid Price Exclusive of GST (PKR)	Inland Transportation Charges	Remarks
	Technical (If Applicable)	Financial (If Applicable)				
M/s. Pak Electron Limited, Lahore.	NIL	NIL	66,500,000/-	66,500,000/-	500,000/-	Responsive
M/s Bambang DJAJA (B&D Transformer), Indonesia	<p>Reasons of Non-Responsiveness</p> <p>Following are the reasons of non-responsiveness of the bidder:</p> <ul style="list-style-type: none"> a) The bidder has mentioned short circuit duration to be 2 seconds instead of required 3 seconds as per requirement of NTDC Specification P-46:2008. b) The design flux density quoted by the bidder is 1.72 Tesla which will make maximum flux density at over voltage operation equals to 2.0984T which is much higher than required value 1.9 Tesla as per clause 4.6.3 of P-46:2008. c) Asymmetrical Short Circuit Current values mentioned in SOTD at Sr. No. 24(a) (i&ii) are 40kA for both HV & LV windings against required values 2.73kA & 28.16kA. d) The lightning impulse voltage test on LV side of the offered power transformer quoted by the bidder is mentioned as 75kV instead of required 110kV as per tender specification. 					

- | | |
|--|--|
| | <ul style="list-style-type: none"> e) The separate source power frequency test voltage for LV Winding is mentioned as 28kV instead of required value 38kV as per tender specification. f) The schedule of technical data submitted with the bid is not properly filled. g) The bidder didn't provide undertaking of bid security on non-judicial stamp paper as per requirement of Appendix-Q of tender document. h) The bidder neither provided type test reports of offered 132/11.5kV, 20/26MVA Power Transformer nor submitted any undertaking to perform type testing as per requirement of clause 3 Section VI of tender document. i) The bidder did not submit comfort letter from any scheduled bank of Pakistan. j) Submitted power of attorney is not duly attested by Pakistan Embassy/Consulate General of Pakistan. |
|--|--|

1. Lowest Evaluated Responsive Bidder

M/s. Pak Electron Limited, Lahore.

2. Any other additional/supporting information, the procuring agency may like to share

Nil

Signature _____

Official Stamp CHIEF ENGINEER (MP&M) NTDC

Note: The above evaluation results are based on detailed Bid Evaluation Report (BER) and correct to best of our knowledge, however, in case of any discrepancy, the content of original BER shall prevail