

**(TECHNICAL) EVALUATION REPORT**  
**(As Per Rule 35 of PPRa Rules, 2004-Revised 2021)**

1. Name of Procuring Agency

National Transmission and Despatch Co. Ltd (NTDCL)

2. Method of Procurement

International Competitive Bidding (ICB)

3. Title of Procurement

PROCUREMENT OF 220KV & 132KV CIRCUIT BREAKERS FOR EVACUATION OF POWER FROM HAMPIR WIND FARM.

4. Tender Inquiry No.

NOR-70BR4-2021

5. PPRa Ref No.

TS448172E

6. Date & Time of Bid Closing

15/04/2021 11:00 A.M.

7. Date & Time of Bid Opening

Technical: 15/04/2021 11:30 A.M.

Financial: To be opened

8. No of Bids Received

Lot	I	II
No. of Bids	02	01

9. Criteria for Bid Evaluation

Evaluation and Comparison of Bid as per Section-I "Instructions to Bidders" of Bidding Documents

10. Details of Bid(s) Evaluation

**LOT-I: (245 KV Circuit Breakers)**

Name of the Bidders	Marks		Technical Evaluation Result (Responsive/Non-Responsive)	Remarks
	Technical (If Applicable)	Financial (If Applicable)		
M/s. Pinggao Group Company Limited	NIL	NIL	Responsive and recommended for price bid opening	
M/s. Electric International Harbin	NIL	NIL	Non-Responsive	The bidder is non-responsive due to following reasons a) The delivery & Completion Schedule (Schedule-C to Bid)

2ntdc 19721. 0

e38304

Company China			<p>submitted with the bid shows major deviation in Delivery Period Offered. As per requirement of tender document, the <b>required delivery period is of 240 days</b> from Signing of contract agreement. However, the bidder offered delivery period of 7 Months with following conditions instead of criteria defined in tender document:</p> <p>1) From the date of issuing of L/C</p> <p>2) From the date of acceptance of type test report by the purchaser, which is latest.</p> <p><i>Therefore, the bidder doesn't fulfill the requirement of delivery &amp; completion schedule as laid down in clause 12 Section-IV of tender document.</i></p> <p>b) Regarding routine testing, the bidder doesn't comply with tender specification. The requirement for routine testing as per tender specification P-171:2008 is that all the routine tests will be carried out on each offered circuit breaker while the bidder quoted that: <i>"The general practice of routine tests witness is that witnessing of routine tests is carried out on no more than 10% of ordered units. However, all units are routine tested. The equipment prices quoted do not include any special arrangement exceeding above routine test witness arrangement. In case any special witness arrangements are required, they will be charged separately."</i></p> <p>Therefore, the bidder doesn't fulfill the requirement of <b>routine testing</b> as laid down in <b>clause 26.1 Section-IV</b> of tender document.</p> <p>c) The liquidated damages mentioned by the bidder are <b>0.01%</b> of total contract price per day of delay instead of required <b>0.05%</b>. Therefore, the bidder doesn't fulfill the requirement of liquidated damages as laid down in clause 27.1 Section-IV of</p>
---------------	--	--	--

				tender document. These discrepancies come into major deviations; therefore, the bid is not substantially responsive as per clause IB.30 Section 1 of bidding document. Hence, the bidder is considered as non-responsive
--	--	--	--	---

**LOT-II (145kV Circuit Breaker)**

Name of the Bidders	Marks		Technical Evaluation Result (Responsive/Non-Responsive)	Remarks
	Technical (If Applicable)	Financial (If Applicable)		
M/s. Harbin Electric International Company China	NIL	NIL	Non-Responsive	Same Reasons as stated in above Lot

**11. Bidders declared technically responsive**

Lot-I: M/s. Pinggao Group Co. Ltd. China  
Lot-II: None

**12. Any other additional/supporting information, the procuring agency may like to share**

NIL

Signature \_\_\_\_\_

Official Stamp \_\_\_\_\_

*Note: The information is being published under PPRA Rules Revised June-2021 for information of all stakeholders.*