



FAISALABAD ELECTRIC SUPPLY CO. LTD.

☎ 041-9220397
☎ 041-9220691
✉ cedevfesco@yahoo.com

Office of the,
Chief Engineer (Development),
PMU FESCO Faisalabad

32
24

EVALUATION REPORT

(As per Rule 35 of Public Procurement Rules, 2004)

- Name of Procuring Agency: Faisalabad Electric Supply Company (FESCO)
- Method of Procurement: Single Stage Single Envelope
- Title of Procurement:
 - 132 KV Metal oxide surge arrester alongwith steel supporting structure, terminal connectors & Grouting bolts.
 - 132 KV Metal oxide surge arrester for 132KV capacitor bank alongwith steel supporting structure, terminal connectors & Grouting bolts.
 - 11 KV Metal oxide Surge Arrester alongwith steel supporting structure, terminal connectors & grouting bolts.
- Tender Inquiry No.: NCB-660/FESCO/PMU/GSC(DEPOSIT-WORK)/2024-25
- PPRA Ref. No. (TSE): TS543227E dated 10.07.2024
- Date & Time of Bidding Closing: 11:00 A.M. 12.08.2024
- Date & Time of Bidding Opening: 12:40 P.M. 12.08.2024
- No. of Bids Received: 02 Nos.
- Criteria for Bid Evaluation: As per Bidding Document
- Details of Bids (s) Evaluation: As under:

Name of Bidder	Marks		Evaluated Cost (Million Rs.)	Rule/Regulation/SBD/Policy/Basis for Rejection/Acceptance as per Rule 35 of PP Rules, 2004
	Technical (If applicable)	Financial (If applicable)		
Muthair Metal Works (Pvt) Ltd	---	---	16.581	The bid declared Commercially & Technically Responsive .
EMCO Industries Ltd	---	---	09.633	<ol style="list-style-type: none">The bid declared Commercially Responsive.The bid declared Technically Non-Responsive due to:-<ul style="list-style-type: none">The bidder did not submit type test report for 11 KV Metal oxide Surge Arrester and an unconditional undertaking that in case of award of contract, if submitted type test reports are not according to NTDC type test policy, he will carry out fresh type tests under witness of NTDC/DISCO's Inspectors as per NTDC revised type test policy within the quoted Bid price and without affecting the delivery / completion period as mentioned in the Bidding

13 fes w 25921. ✓

				Documents. <u>The bidder has not complied with Clause 7.3 (Type Tests Report), Section-III, Evaluation and Qualification Criteria of Bidding Documents.</u>
--	--	--	--	---

Lowest Evaluated Bidder: M/s Mutahir Metal Works (Pvt) Ltd, Lahore

11. Any other additional/supporting information, the procuring agency may like to share.

Endst. No. 8786-87 /CE(Dev)PMU FESCO

Dated: 23-9-24

Forwarded to the Deputy Director, Public Procurement Regulatory Authority, 1st Floor, FBC Building, Near State Bank, Sector G-5/2, Islamabad for uploading at PPRA Website.

Chief Engineer (Development)
PMU, FESCO, Faisalabad

CC:-

1. Director General (IT) FESCO Faisalabad with the request to upload on FESCO website please.
2. Master File.