FAISALABAD ELECTRIC SUPPLY CO: LTD:





= 041-9220691

cedevfesco@yahoo.com

Office of the, Chief Engineer (Development), PMU FESCO Faisalabad

EVALUATION REPORT (As per Rule 35 of Public Procurement Rules, 2004)

- Name of Procuring Agency
- 2 Method of Procurement
- 3 Title of Procurement

Faisalabad Electric Supply Company (FESCO)

Single Stage Single Envelope

- i) Three Phase Power Transformer Testing Set Make UK/EU/USA or equivalent, Measures Turn Ratio, Measure Winding Resistance, Core Demagnetization Module, Short Circuit Lmp./Leakage, Reactance Module, High Voltage Capacitance and Dissipation/Power Factor Testing Device, Excitation Current with upto 12kV, Testing of on Load Tap Changer, Operating Temp upto 55, Works on 230Volt 50Hz, Weight of per unit not more than 25Kg, Transport cases for test set and Accessories, Soft Bag & Trolley for Test Set.
- ii) Circuit Breaker Timing Test Set Make USA/UK/EU or equivalent can test with both sides of breaker grounded, reliable & accurate test results in noisy high voltage substation, have preprogrammed sequences, operating Temperature 0-50, Weight less than 15 kG (set), no of control channels 3, 6 isolated channels for timing section, voltage mode inaccuracy 1%, Sampling rate > 35kHz, 10 m connecting cables with reels, transport case for set and cables, with all allied accessories
- iii) Transformer Oil Break Down Voltage Test Set Make USA/UK/EU or equivalent 0-100kV output voltage. Internal Test Result Memory, Tough Display and 1 Unit Chamber for Oil Sample, Transport Case, Voltage Rise Set from .5V/s to 10V/s, Evolution Standards available, Internal and external printer option available
- iv) Universal Relay Test Set including Software and Laptop Make UK/EU/USA or equivalent, Works on 100-230VAC 50 Hz, Auxiliary Supply DC 0-260DC, 04 No. Binary Output, Four Voltage Output 4*300V or 2*600V, Six Current Output 6*32A, 430VA Burden, Socket 3*32A, Generator Combination Multifunctional Inputs, Binary (Dry/Wet), Integrated Network for Testing of IEC 61850 IEDs, Frequency Range 10-1000Hz, Compete Auto Test Feature of Over current, Differential, Distance Relays etc, Injection faults of LN LL LLN LLL LLLN in Over current, Differential and Distance Relays can also test bus bar n line differential relays, Output short circuit protected, Time Synchronization, Operating Temperature 0-50oC, Safety Standards IEC 61010-1 & 61010-2-6, Weight less tan 20Kg (Set), PC connection (Ethernet, USB A n USB B), Able to import "xrio" files, Heavy Duty



DiVISCANISO Data 2/03-34 futbor-Undoorton Report Profession &

Transport case with wheels and extendable handle, All accessories, Software to test all relays, Latest Laptop i7. 10th Generation, Display 15.6" HFD, 16GB RAM, 2GN Grajocs Card, 256TB SSD with Carry Bag and Charger

v) Ferrule printing machine 230V AC, cable ID printer for control cable

Tender Inquiry No. 4

NCB-473/PMU/FESCO/GSC/2023-24

5 PPRA Ref. No. (TSE) TS514149E dated 26.06.2023

6 Date & Time of Bidding Closing

11:00 A.M. 01.08.2023

Date & Time of Bidding

11:45 A.M 01.08.2023

Opening

No. of Bids Received

05 No.

9 Criteria for Bid Evaluation As per Bidding Document

Details of Bids (s) Evaluation 10

As under:

| Name of Bidder | Marks | | Evaluated | Rule/Regulation/SBD/Policy/Basis for | | |
|-------------------------------------|------------------------------|------------------------------|-----------------------|--|--|--|
| | Technical (If applicable) | Financial (If applicable) | Cost (Million Rs.) | Rejection/Acceptance as per Rule 35 of PP Rules, 2004 | | |
| Prescon Engineering (Pvt) Ltd | | | 39.390 | The bid declared Commercially & Technically Non-Responsive because the bidder did not submit copies of at least 02 No. contracts successfully completed within the last five (05) years for serial No.2, the schedule of technical data submitted with the bid for serial No.2 is not conforming to tender specification & pot bid clarification letter did not accepted by evaluator as per clause-29 of Section-I. | | |
| Bismillah Enterprises | | | 27.800 | The bid declared Commercially Non-Responsive because the bidder does not have Average Annual Turnover in the last three years more than two times of the quoted price | | |
| Sarwar Electronics | | | 85.400 | The bid declared Commercially & Technically Responsive for Serial No.01, 02, 03 & 04 | | |
| AYK (Pvt) Ltd | | | 82.173 | The bid declared Technically Non-Responsive because the schedule of technical data submitted with the bid for serial No.1 is not conforming to tender specification | | |
| Uni-Com Corporation | | | 1.950 | The bid declared Commercially Non-Responsive because documents comprising the bid as per Clause 11, Section-I are not attached. Audit Report for last three (03) years is not provided as required in Clause (Financial Criteria), Section-III & the bidder did not submit copies of at least 02 No. contracts successfull completed within the last five (05) years | | |

Lowest Evaluated Bidder:

M/s Sarwar Electronics, Lahore for Item No.01, 02, 03, 04 and No. bidder responsive for Item No.05

| 11. | Any other add | ditional/supporting | information, | the procuring | agency may | like to share. |
|-----|---------------|---------------------|--------------|---------------|------------|----------------|
|-----|---------------|---------------------|--------------|---------------|------------|----------------|

Endst. No. 1750-51

/CE(Dev)PMU FESCO

Dated: 05-09-23

Forwarded to the Deputy Director, Public Procurement Regulatory Authority, 1st Floor, FBC Building, Near State Bank, Sector G-5/2, Islamabad for uploading at PPRA Website.

Chief Engineer (Development)

CC:-

- 1. Director General (IT) FESCO Faisalabad with the request to upload on FESCO website please.
- 2. Master File.

DOSCRESO Data 2023-24 Letters Evaluation Report Proformation