

PAKISTAN TELEVISION CORPORATION LIMITED

Federal TV Complex
Constitution Avenue,
F-5/1, Islamabad,

Ref No. ENG/CEE/PFI610

March 27, 2024

CORRIGENDUM

This is reference to purchase enquiry No. ENG/CEE/PFI/579 dated 01-03-2024 and corrigendum for date extension dated March 20, 2024 for the Supply, installation and testing of Power Factor improvement units was uploaded on the website of PTV & PPRA, due to less participation from supplier/bidder tender opening date is being once again extended up to 03-04-2024 at 11.00 AM. All other terms and conditions of the tender will be remain same.



(MUHAMMAD ARIF)
Deputy Controller Engineering (Elec)
Ph; 9222339, 9077366

PAKISTAN TELEVISION CORPORATION LIMITED

Federal TV Complex
Constitution Avenue,
F-5/1, Islamabad,

Ref No. ENG/CEE/PFI601

March 20, 2024

CORRIGENDUM

This is reference to purchase enquiry No. ENG/CEE/PFI/579 dated 01-03-2024, for the Supply, installation and testing of Power Factor improvement units was uploaded on the website of PTV & PPRA, due to less participation from supplier/bidder tender opening date is being extended up to 27-03-2024 at 11.00 AM. All other terms and conditions of the tender will be remain same.



(MUHAMMAD ARIF)
Deputy Controller Engineering (Elec)
Ph; 9222339,9077366

PAKISTAN TELEVISION CORPORATION LIMITED

ENG/CEE/PFI/579

PTVC intends to invite technical prequalification and price tender (on single stage two envelope procedure) as per PPRA rule 36B for the Supply, installation and testing of following rating capacity Power Factor improvement units with mentioned technical specifications/sites.

03 No's 25 KVAR PFI UNITS L.T PANEL FOR RBS MURREE OF EACH SPECIFICATION				
Sr#	Items	Rating	Brand	QTY
1	MCCB TP	60 A, 10 KA	Schneider/equivalent	1
2	CAPACITOR	12.5 KVAR	Groupo Energia/ equivalent	2
3	POWER FACTOR CONTROLLER	7 STEPS	TENSE/ equivalent	1
4	CONTROL RELAY	220 V, AC	IMO/ equivalent	1
5	MAGNETIC CONTACTOR	25 A, AC3	Schneider/equivalent	2
6	C.T	100/5 A	FICO/ equivalent	1
7	HRC FUSE with base	35 A	KP/ equivalent	6
8	CONTROL FUSE PANEL	2 A	KP/ equivalent	3
9	SELECTOR SWITCH	3 POS	TEL/ equivalent	1
10	INDICATION LIGHT	220 VAC	NIN/ equivalent	3
11	INDICATION LIGHT PFI	220 V	NIN/ equivalent	2
12	BUS BAR SET	25X3 mm	COPPER	1
13	L.T PANEL LOOP CABLE	1-Core 20 mm sq	PCL/ equivalent	30 rft.
14	METAL ENCLOSURE (HXWXD)"	30X24X6	Wall Mounted 16 SWG	1

02 No's 30 KVAR PFI UNITS FOR RBS SAHIWAL AND 01 NO. FOR RBS TANDO ALLAH YAR OF EACH SPECIFICATION				
Sr#	Items	Rating	Brand	QTY
1	MCCB TP	60 A, 10 KA	Schneider/equivalent	1
2	CAPACITOR	12.5 KVAR	Groupo Energia/equivalent	2
3	CAPACITOR	5 KVAR	Groupo Energia/equivalent	1
4	POWER FACTOR CONTROLLER	7 STEPS	TENSE/ equivalent	1
5	CONTROL RELAY	220 V, AC	IMO/ equivalent	1
6	MAGNETIC CONTACTOR	25 A, AC3	Schneider/equivalent	2
7	MAGNETIC CONTACTOR	9 A, AC3	Schneider/equivalent	1
8	C.T	100/5 A	FICO/ equivalent	1
9	HRC FUSE with base	35 A	KP/ equivalent	6
10	HRC FUSE with base	25 A	KP/ equivalent	3
11	CONTROL FUSE PANEL	2 A	KP/ equivalent	3
12	SELECTOR SWITCH	3 POS	TEL/equivalent	1
13	INDICATION LIGHT	220 VAC	NIN/equivalent	3
14	INDICATION LIGHT PFI	220 V	NIN/equivalent	2
15	BUS BAR SET	25X3 mm	COPPER	1
17	L.T PANEL LOOP CABLE	1-Core 20 mm sq	PCL/equivalent	30 rft.
18	METAL ENCLOSURE (HXWXD)"	30X24X6	Wall Mounted 16 SWG	1

01 No. 75 KVAR PFI UNIT L.T PANEL FOR RBS SAKESAR SPECIFICATION				
Sr#	Items	Rating	Brand	QTY
1	MCCB TP	150 A, 18 KA	Schneider/equivalent	1
2	CAPACITOR	25 KVAR	Groupo Energia/equivalent	2
3	CAPACITOR	12.5 KVAR	Groupo Energia/equivalent	2
4	POWER FACTOR CONTROLLER	12 STEPS	TENSE/ equivalent	1
5	CONTROL RELAY	220 V, AC	IMO/ equivalent	1
6	MAGNETIC CONTACTOR	40 A, AC3	Schneider/equivalent	2
7	MAGNETIC CONTACTOR	25 A, AC3	Schneider/equivalent	2
8	C.T	100/5 A	FICO/ equivalent	1
9	HRC FUSE with base	63 A	KP/ equivalent	6
10	HRC FUSE with base	25 A	KP/ equivalent	6
11	CONTROL FUSE PANEL	2 A	KP/ equivalent	3
12	SELECTOR SWITCH	3 POS	TEL/ equivalent	1
13	INDICATION LIGHT	220 VAC	NIN/ equivalent	3
14	INDICATION LIGHT PFI	220 V	NIN/ equivalent	2
15	BUS BAR SET	30X4 mm	COPPER	1
16	L.T PANEL LOOP CABLE	1-Core 70 mm sq	PCL/ equivalent	30 ft.
17	METAL ENCLOSURE (HXWXD)"	36X24X7	Wall Mounted 16 SWG	1

TERMS & CONDITIONS:

- 1- Company/supplier/contractor should be an active tax payer.
- 2- Copy of NTN and GST certificates must attach.
- 3- Copy of PEC of relevant code (EE04) for low volts certificate must attach.
- 4- Delivery/installation schedule be mentioned.
- 5- Prices must be inclusive of GST and all other taxes for each site.
- 6- All government taxes are applicable.
- 7- Payment will be after delivery/physical on load inspection at above sites.
- 8- Earnest Money @ 2% of quoted price in the shape of Demand Draft/Pay order, in favor of PTVC, be attached with price tender, this will be retained till the finalization of the case. Personal cheques as earnest money will not be acceptable.
- 9- Guarantee /Warranty period should not be less than 12 months from date of testing.
- 10- PTVC will retain 5% of bid value till the successful completion of Guarantee/warranty period.
- 11- Price quoted should be valid for 120 days.
- 12- No cutting/overwriting in rates/prices will be allowed in financial bids.
- 13- No modification in proposal after submission of bids shall be allowed.
- 14- Tenders received after due date or incomplete shall not be entertained.
- 15- Documents along with proper tax invoice, Annexure C, etc will be required at time of submission of the bill.
- 16- Company/Manufacturer brochure/Catalog must be attached with quotation.
- 17- Affidavit of not blacklisted from any govt. /involved in any fraud cases.
- 18- PTVC increase or decrease PFI units as per site requirement.
- 19- PTVC reserves the rights to reject all bids or proposals and ground of rejection will be communicated to the parties if requested but there will be no binding on PTVC to justify those grounds.

Sealed quotations having two separate envelopes marked as "TECHNICAL PROPOSAL AND FINANCIAL PROPOSAL IN A SINGLE PACKAGE SHOULD BE ADDRESSED TO CONTROLLER AUDIT, CHAIRMAN SENIOR TENDER COMMITTEE PTV-HQRS OFFICE CONSTITUTION AVENUE ISLAMABAD ON OR BEFORE 20-03-2024 AT 11.00 AM". The main envelope should clearly mention offer for PFI Units. Technical proposals will be opened on the same day at 11:30 AM in presence of bidders/agents who may like to attend. The financial proposal of technically qualified parties will be opened later and time of opening of financial proposal will be communicated to the technically qualified parties.


 [MUHAMMAD ARIF]
 Deputy Controller Engineering (Elect)
 Ph# 051-9222339, 9077366