

PAKISTAN TELEVISION CORPORATION LIMITED

ENG/CEE/GEN/530

PTVC intends to invite technical prequalification and price tender (on single stage two envelope procedure) for the Supply/installation of 01 No.300 KVA, 3-phase Generator (Perkins, Cummins, Caterpillar or equivalent) of the following technical specifications/features.


S.No	Description	Specification
1	Generator rating	300 KVA , (outdoor)
2	Type of Engine/Fuel	6 cylinder/Diesel/Turbo charger
3	Connection	3-phase,4-wire,380-415 volts
4	Coupling system of Alternator and Engine	Direct couples by means of SAE flange
5	Power factor	0.8-0.9
6	Frequency	50 Hz
7	RPM	1500
8	Protections	Overload, short-circuit, over temp, over/under speed, low oil pressure
9	Equipped with	<ul style="list-style-type: none"> • ATS/AMF Panel (with bypass/delay timer mechanism) • Manual/Key options • All type cables as per site requirements • Sound proof canopy with weather proof paint • Tool kit, • Operation/ Maintenance Manual. • Circuit diagram(English version)
10	Monitoring/display system	<ul style="list-style-type: none"> • Volts 3-phase L-L, L-N • Amp/Ph & average • Frequency • Battery Volts • Engine Hr Meter • Lubricant oil pressure • Water Temp • Engine Speed • Alarm indication
11	Alternator Control system	Electronically/AVR
12	Engine Control system	Electronic Governor Control
13	Cooling system	Water/Oil/Air Cooled
14	Fuel tank	<ul style="list-style-type: none"> • Separate fuel tank up to 600 Ltrs capacity showing gauge and mounted about 2-3 ft high from engine level.
15	Mounting Arrangement	Heavy duty fabricated steel base frame with anti vibration rubber mounting
16	Engine Exhaust System	As per site requirement

Term and Conditions:

- 1- Company/supplier/contractor must provide detail offer make/model on letter head.
- 2- Company/supplier/contractor should be an active tax payer.
- 3- Up to date Copy of NTN and GST certificates and PEC License with relevant code.
- 4- Delivery schedule be mentioned.
- 5- Prices must be lump sum inclusive of GST and all other taxes.
- 6- All government taxes are applicable.
- 7- Payment will be after delivery /successful installations.
- 8- Earnest Money @ 2% of quoted price in the shape of Demand Draft/Pay order, in favor of PTVC, be attached with price tender, this will be retained till the finalization of the case however personnel will not acceptable.
- 9- Personnel cheques will not be acceptable.
- 10- Guarantee /Warranty period should not be less than 12 months from date of testing.
- 11- PTVC will retain 10% of bid value till the successful completion of Guarantee/warranty period.
- 12- Tenders received after due date or incomplete shall not be entertained.
- 13- Documents along with proper tax invoice, Annexure C, etc will be required at time of submission of the bill.

- 14- Company/Manufacturer brochure/Catalog must be attached with quotation.
- 15- Affidavit of not blacklisted from any govt/involved in any fraudulent cases.
- 16- For solving dispute if occur will be solve only in Islamabad jurisdiction area.
- 17- The delivery of material at PTV NEWS Islamabad will be on bidders risk and cost.
- 18- No cutting/overwriting in rates/prices will be allowed in financial bids.
- 19- No modification in proposal after submission of bids shall be allowed.
- 20- Company/supplier/contractor must visit the site before submitting proposals.
- 21- PTVC reserves the rights to reject any or all proposals as per PPRA rule 33 and ground of rejection will be communicated to the parties if requested but there will be no binding on PTVC to justify those grounds.

Sealed quotations having two separate envelopes of Technical proposal and financial proposal in a single package should be addressed to Controller Audit, Chairman Senior Tender Committee PTV-HQrs Office Constitution Avenue Islamabad on or before 17-04-2024 at 11.00 AM. Technical proposals will be opened on the same day at 11:30 AM in presence of bidders/agents who may like to attend. The financial proposal of technically qualified parties will be opened later and time of opening of financial proposal will be communicated to the technically qualified parties. The main envelope should clearly mention offer for 300 KVA generator.


[MUHAMMAD ARIF]

Deputy Controller Engineering (Elect)
PTV-HQrs. office Islamabad
Ph# 051-9222339,9077366